

ENERGY AUDIT AT THYCATTUSSEERI INTAKE PUMP HOUSE , PIRAVAM"



Energy Audit Report
Year: 2020-21



Energy Management Centre – Kerala
Dept of Power, Govt of Kerala.State Designated Agency
Sreekrishna Nagar, Sreekariyam P.O., Thiruvananthapuram – 695 017
Ph: 0471 - 2594922, 2594924,Fax: 0471 – 2594923
e-mail: emck@keralaenergy.gov.in

Save Energy Save our Planet

Energy Management Centre - Kerala
Department of Power, Government of Kerala
Sreekariyam P.O., Thiruvananthapuram 695017
Email : emck@keralaenergy.gov.in, Web : www.keralaenergy.gov.in

This Page is Intentionally Kept Blank

ENERGY AUDIT REPORT
THYCATTUSSEERI INTAKE PUMPHOUSE
PIRAVAM



Energy Audit Report
INTAKE PUMPHOUSE, PIRAVAM

Report No: EA 584

2020-October

Energy Audit Team:

Suresh Babu B V, Accredited Energy Auditor, AEA 33

B. Zachariah, Chief Technical Consultant

Abin Baby, Project Engineer

Mahesh Ramachandran E, Project Engineer

Mohammed Aneez, Project Engineer

Accredited Energy Auditor, AEA 33
Bureau of Energy Efficiency
Government of India

Empaneled Energy Auditor, EMCEEA-0211F,
Energy Management Centre
Government of Kerala.

Acknowledgment

We were privileged to work together with the administration and staff of Kerala Water Authority Intake Pump House, Aluva for their timely help extended to complete the study and bringing out this report on Energy Audit.

We are happy to acknowledge the help extended by Sri. Sojan Jacob, AE, HW Section, Thycattussery and his colleagues for their quality interactions and advices to make this audit complete.

We thank our consultants, engineers and backup staff for their dedication to bring this report.

Thank you.

B V Suresh Babu
Accredited Energy Auditor
AEA 33, Bureau of Energy Efficiency
For OTTOTRACTIONS

This Page is Intentionally Kept Blank

Contents

	Acknowledgement	
	Certification	
	Executive Summary	
1.	Introduction	1-3
2.	Process and Functional Description	4-5
3.	Energy and Utility system Description	6-7
4.	Detailed Process flow diagram and Energy& Material balance	8-9
5.	Performance evaluation of major equipment and systems	10-18
6.	Energy Efficiency in Utility and Process Systems	19-20
7.	Evaluation of Energy Management System	21-23
8.	Energy Conservation Options & Recommendations	24-31
	Technical Supplements	
9.	Technical Supplement 1, Backup data& Worksheets	32-38
10.	Technical Supplement 2, Power Quality Analysis	39-64
11.	Notes	

This Page is Intentionally Kept Blank

Certification

This is to certify that

The data collection has been carried out diligently and truthfully;

All data monitoring devices are in good working condition and have been calibrated or certified by approved agencies authorised and no tampering of such devices has occurred;

All reasonable professional skill, care and diligence had been taken in preparing the energy audit report and the contents thereof are a true representation of the facts;

Adequate training provided to personnel involved in daily operations after implementation of recommendations; and

The energy audit has been carried out in accordance with the Bureau of Energy Efficiency (Manner and Intervals of Time for the Conduct of Energy Audit) Regulations, 2010.

SURESH BABU B V
ACCREDITED ENERGY AUDITOR (AEA 33)

This Page is Intentionally Kept Blank

OTTOTRACTIONS- ENERGY AUDIT						
Executive Summary						
Consolidated Cost Benefit Analysis of Energy Efficiency Improvement Projects						
KWA RAW WATER PUMPING STATION, PIRAVAM						
Sl No	Projects	Investment	Cost saving	SPB	Energy saved	
		(Lakhs Rs)	(Rs)/Yr	Months	kWh/Yr	toE/Yr
1	Energy Saving in Lighting by replacing existing 28 No's T8 Lamps to 18W LED Tube	0.10	0.27	4.43	6623	0.57
2	Energy Efficiency in Existing Pumping system by replacing inefficient motor (RWPH HT 2)	67.65	102.93	7.89	1413864	121.59
3	Energy Efficiency in Existing Pumping system by replacing inefficient motor (RWPH HT 3)	67.65	79.00	10.28	1316628	113.23
4	Energy Efficiency in Existing Pumping system by replacing inefficient motor (RWPH HT 4)	67.65	88.98	9.12	1483068	127.54
	Total	203	271	8	4220183	363

This Page is Intentionally Kept Blank



1

Introduction





A detailed energy audit has been carried out at **KERALA WATER AUTHORITY RAW WATER PUMPING STATION, PIRAVAM** in September 2020. **Energy Management Centre – Kerala (EMC)** has entrusted OTTOTRACTIONS an Accredited Energy Auditor of Bureau of Energy Efficiency and Empaneled Energy Auditor of Energy Management Centre, Government of Kerala to conduct this audit for EMC. The energy audit has identified energy conservation opportunities and recommended projects to improve energy efficiency of the facility.

About EMC-Kerala

Kerala Government has become the first State Government in India to establish an **Energy Management Centre (EMC)** at State level, aiming primarily to remould and instrumentalise energy sector as a catalyst in promoting a development process which is econo-ecologically sustainable. With a view to making energy sector achieve such a lead and catalytic role, EMC has evolved a novel and comprehensive energy management approach and institutional philosophy encompassing management of energy technology systems - both conventional and non-conventional, energy conservation in all sectors of the economy, energy resource management, rural and urban energy systems, energy education and training, energy generation and conservation based employment and poverty alleviation programmes.

India, one of the most affected countries in terms of energy shortage and increasing energy price became one such country in the world to adopt energy management measures at the earliest in all sectors of the economy on a priority basis, including popularising and promoting renewable energy technology and resources.

When liberalization and globalization of economy take effect, energy management aimed at enhancing total energy efficiency in all sectors of the economy becomes a major factor in determining the comprehensive competitiveness of the economy.



Giving due consideration to this energy-economy interaction process/scenario, the Government of Kerala took leadership initiatives for establishing a multi-disciplinary Energy Management Centre under the Department of Power.

This energy audit report complies with the clauses in *Energy Conservation Act, 2001* on mandatory energy audit (Form 4 [refer regulation 6(2)] guidelines for preparation of energy audit report) and complies with the G.O (Rt) No.2/2011/PD dated 01.01.2011 issued by Government of Kerala on mandatory energy audit.

1.1. General plant/establishment details and descriptions

Kerala water authority was established in first April 1984 under Kerala water and waste water ordinance. The Aluva PH Head works subdivision with consumer numbers 10/1010 (1355670000844) & 23/2357 (1355670001036) have four plants. Plant -1 established in the year 1965, Plant - 2 in 1977, Plant-3 in 1992 and plant-4 in 2002 at the head works Aluva. It has an installed capacity of 225 MLD (million liters per day) with 365 days working for all four plants together.

Base line Data (Electrical System)	
Code	EA 584
Facility	RAW WATER PUMP HOUSE
Provider	KSEB Ltd
Consumer No	1355970011349
Contract Demand (kVA)	921
Tariff	HT1(A) Industrial
Energy Charge Rs/ kWh Z1	5.5
Energy Charge Rs/ kWh Z2	8.25
Energy Charge Rs/ kWh Z3	4.125
Demand Charge Rs/ kVA	300
Excess Demand Rs/kVA	150
Energy Bill Analysis interval	2018-19



1.2. Energy audit team

The Energy Audit team is listed below. Besides this list various domestic experts also participated in this project.

1. Suresh Babu B V, Accredited Energy Auditor, AEA 33
2. B. Zachariah, Chief Technical Consultant
3. Abhijith M R, Certified Energy Auditor
4. Abin Baby, Project Engineer
5. Mahesh Ramachandran E, Project Engineer
6. Mohammed Aneez, Project Engineer

1.3. Component of production cost

1. Energy (Electricity)
2. Manpower (Permanent & Contract)
3. Consumables
4. Overhead & others

1.4. Major energy use areas

Electricity from KSEB 100% holds the share in the total energy consumed in this facility.


2

Production process description



The Raw water Pump house located at Piravam have an installed capacity of 107 MLD. The plant commissioned in 2012, is feedig raw water to the WTP located at Thycattussery. It has four raw water pumps having 400kW rating. At a time only one pump is in operation now and now delivering approximately 27000 m³ of treated raw water into the WTP Thycattussery. Taking water from the Movatupuzha river.

The single line diagram of the system is given below.



3

Energy and utility system description



KVVA intake Pump house, Trivani



3.1. List of utilities

Electricity is only fuel used in the facility.

3.2 Brief description of each utility

3.2.1 Electricity


The facility is a consumer of Kerala State Electricity Board (KSEB) under HT – I (A) Industrial Tariff category at 11 kV. The facility having two HT connections with contract demand of 921 kVA. The details of transformer installed in the facility are given below.


Details of Transformers				
Sl.No	Make	Year of manufacturing	Rating (kVA)	Voltage (kV)
1	INDO TECH	2009	1600	3.300
2	INDO TECH	2009	1600	3.300
3	INDO TECH	2009	600	0.440
4	INDO TECH	2009	600	0.440

The power factor is being maintained as .97 in this facility. The electrical load study and power quality analysis has been conducted and the results and reports are given in the “Technical Supplement” of this report.

4

Detailed process flow diagram and energy and material balance






The energy balance of this facility is given above. The auxiliary loads cater 3% of the total load

Plant Operation

The Pumping Station has 4 transformers, out of 2 numbers are 11kV/3.3kV HT transformers and 2 numbers are 11kV / 440 V LT transformers.



5

Performance evaluation of major utilities and process equipment's/systems.



5.1. List of equipment and process where performance testing was done.

- Electrical System
- Pumps
- Lighting System
- Renewable Energy


5.2. Results of performance testing

5.2.1. Electrical System


The average unit cost of electricity is **7.28 Rs/kWh**. This is taken as the basis for the financial analysis of electrical energy efficiency projects. The information on average energy consumption is taken from the historical electricity bill analysis. The electricity is fed from centralized substations. The Maximum demand observed during electricity bill analysis was 431 kVA.

Electricity Consumption


The Electricity consumption details for the financial year 2018-19 is plotted below. The Total consumption was found to be 31.09 Lakhs Units in the year 18-19.



The Zone wise Energy Consumption Profile is shown below ,which shows 38% of total energy consumption in a day is at normal hours, 30% at peak hours and 32% at non peak hours.




The electricity cost profile for the year 2018-19 is given below.



The details of production and flow readings are given in the technical supplement

Power Factor

The average power factor observed is 0.97 which is very low. From load study the required capacitance rating is 40kvar. It is strongly recommended to add capacitors to improve power factor to unity. The power factor variation for the financial year 2018-19 is shown below.



During load study it is observed that the power factor average is 0.97(see technical supplement)

Capacitors


The performance study of Capacitor is given below

Capacitor Requirement								
Sl.No	Motors	HP	Make	KW (Rated)	KW (Measured)	Existing PF	Proposed PF	Required kVAR
1	HT Motor No 1	536	KBL	400	359	0.97	1	90.109
2	HT Motor No 2	536	KBL	400	346	0.97	1	86.846
3	HT Motor No 3	536	KBL	400	365	0.97	1	91.615

268 kVAR is the required to improve the power factor to unity.

Demand Control

The facility has a contract demand of 921kVA. As mentioned above the present average power factor of the plant is 0.97 and the average recorded maximum demand is 431 kVA as per historical energy consumption analysis. The electricity demand variation for the financial year 2018-19 is shown below. Demand can be controlled by improving power factor to unity.



5.2.2. Pumps

The list of pumps is given below.

Sl.No		HP	Flow (m ³ /hr)	Make	
				Pump	Motor
1	RWP-1	536	2312.5	Kirloskar	Alstrom
2	RWP-2	536	2312.5	Kirloskar	Alstrom
3	RWP-3	536	2312.5	Kirloskar	Alstrom
4	RWP-4	536	2312.5	Kirloskar	Alstrom

Performance tests of Raw water pumps 1, 2 and 4 were conducted as pump 3 was not working during the audit.

Performance Evaluation of Pumps					
Raw Water Pump House 1 - HT Pump 1					
r Water	Description		Unit	Parameters	
Design Details	General	1	Unit code	KWA PIRAVOM	
		2	Pump ID	RWP 1	
		3	Pump Application	Raw water	
		4	Water Quality	Raw	
		5	Rated head of pump	m	51
	Motors	6	Rated load of the motor	kW	400
		7	Measured load of the motor	kW	359
		8	Efficiency of standard motor	%	94
		9	Type of Motor		SRIM
		10	Motor power	kW	359.00
	Pumps	11	Make		KBL
		12	HP		457
		13	Efficiency	%	85
		14	Combined efficiency of the system (rated)	%	79.90
		15	Combined efficiency of the system (actual)	%	49.69
		16	Volt	KV	3.3
		17	Amps	A	65
		18	rpm	rpm	991
	Pipe Line	19	Material		CI
		20	Size	mm	1200.00
		21	Length	m	NA
Operating Details	Output	22	Water Pumping Details of station (rated Flow)	m ³ /hr	2312.50
		23	Head	m	29
		24	Flow	m ³ /s	0.627
		25	Density of water	kg/m ³	1000
		26	Gravitational Constant	m/s ²	9.81
		27	Hydraulic Power	kW	178.38
		28	Type of Flow Control Mechanism		Throttling
		29	Discharge throttle valve position % open	%	100
		30	Flow Control Frequency		NIL
		31	Working hours per day	Hrs	24
		32	% loading of pump on flow	%	2.34
		33	% loading of pump on head	%	56.86
		34	% loading of motor	%	89.75

Performance Evaluation of Pumps					
Raw Water Pump House 1 - HT Pump 2					
r Water	Description		Unit	Parameters	
Design Details	General	1	Unit code	KWA PIRAVOM	
		2	Pump ID	RWP 2	
		3	Pump Application	Raw water	
		4	Water Quality	Raw	
		5	Rated head of pump	m	51
	Motors	6	Rated load of the motor	kW	400
		7	Measured load of the motor	kW	346
		8	Efficiency of standard motor	%	94
		9	Type of Motor		SRIM
		10	Motor power	kW	346.00
	Pumps	11	Make		KBL
		12	HP		457
		13	Efficiency	%	85
		14	Combined efficiency of the system (rated)	%	79.90
		15	Combined efficiency of the system (actual)	%	51.05
		16	Volt	KV	3.3
		17	Amps	A	62.5
		18	rpm	rpm	991
	Pipe Line	19	Material		CI
		20	Size	mm	1200.00
		21	Length	m	NA
Operating Details	Output	22	Water Pumping Details of station (rated Flow)	m ³ /hr	2312.50
		23	Head	m	28.9
		24	Flow	m ³ /s	0.623
		25	Density of water	kg/m ³	1000
		26	Gravitational Constant	m/s ²	9.81
		27	Hydraulic Power	kW	176.63
		28	Type of Flow Control Mechanism		Throttling
		29	Discharge throttle valve position % open	%	100
		30	Flow Control Frequency		NIL
		31	Working hours per day	Hrs	24
		32	% loading of pump on flow	%	2.33
		33	% loading of pump on head	%	56.67
		34	% loading of motor	%	86.50

Performance Evaluation of Pumps					
Raw Water Pump House 1 - HT Pump 4					
r Water	Description		Unit	Parameters	
Design Details	General	1	Unit code	KWA PIRAVOM	
		2	Pump ID	RWP 4	
		3	Pump Application	Raw water	
		4	Water Quality	Raw	
		5	Rated head of pump	m	51
	Motors	6	Rated load of the motor	kW	400
		7	Measured load of the motor	kW	365
		8	Efficiency of standard motor	%	94
		9	Type of Motor		SRIM
		10	Motor power	kW	365.00
	Pumps	11	Make		KBL
		12	HP		457
		13	Efficiency	%	85
		14	Combined efficiency of the system (rated)	%	79.90
		15	Combined efficiency of the system (actual)	%	49.68
		16	Volt	KV	3.3
		17	Amps	A	66
		18	rpm	rpm	991
	Pipe Line	19	Material		CI
		20	Size	mm	1200.00
		21	Length	m	NA
Operating Details	Output	22	Water Pumping Details of station (rated Flow)	m ³ /hr	2312.50
		23	Head	m	29.2
		24	Flow	m ³ /s	0.633
		25	Density of water	kg/m ³	1000
		26	Gravitational Constant	m/s ²	9.81
		27	Hydraulic Power	kW	181.32
		28	Type of Flow Control Mechanism		Throttling
		29	Discharge throttle valve position % open	%	100
		30	Flow Control Frequency		NIL
		31	Working hours per day	Hrs	24
		32	% loading of pump on flow	%	2.37
		33	% loading of pump on head	%	57.25
		34	% loading of motor	%	91.25

5.2.3. Lighting system

Lighting is one of the major electrical loads connected in the system. T12 and T8 tubes are extensively used in most of the areas and Sodium vapor, Fluorescent etc. in factory/ street lighting. Hardly any LED lights or tubes are used. This is a good component of the load of the facility and replacing these T12 & T 8 tubes with LED tubes can lead to a significant reduction in the load. Good lighting design can reduce costs and have the added benefit of decreasing internal heat gains, thus reducing the need for air conditioning too.

List of Light Loads													
Sl. No.	Location	T12	T8	T5	CFL	LED-B	LED-B (40W)	LED-T	CF	EF	PF	PC	AC (1.5T)
1	Office		4						4			2	2
2	Substation 1		17						8	2			
8	Raw Water PH		8			1		1	1				
Total		0	29	0	0	1	0	1	13	2	0	2	2

All T8 and T12 Lamps shall be replaced with LED tubes or even T5 and the existing CFLs may be shifted to LED in phased manner. Since lighting does not have a separate feeder, the voltage stabilizer cannot be used specifically for this purpose.

This Page is Intentionally Kept Blank

6

Energy efficiency in utility and process system





Specific Energy Consumption (SEC)

OTTOTRACTIONS- ENERGY AUDIT		
Energy Performance Index		
1	Total Production in (MLD)	58
2	Actual annual production M ³	21170000
3	Annual Electricity Consumption (kWh)	3108150
4	Specific Energy Consumption kWh/m³	0.15
5	Specific Energy Consumption m³/kWh	6.81

The specific Energy Consumption is 0.15kWh/m³ for this plant or it may be read as 6.81 m³/kWh consumed.

This value may be taken as internal bench mark for future reference and improvement. As the common headers are used separate SEC for individual pumps are not taken but combined SEC is established. The SEC established includes auxiliary consumption also.

7

Evaluation of energy management system



Energy management policy

There is no written energy policy available. A draft energy management policy is given below. The management may constitute an energy management policy and display the same in the plant to motivate the staff.

KERALA WATER AUTHORITY

PH DIVISION, ALUVA

ENERGY POLICY

(Draft)

We are committed to optimally utilize various forms of energy in a cost effective manner to effect conservation of energy resources. We are committed to conserve the energy which is a scarce resource with the requisite consistency in the efficiency, effectiveness in the cost involved in the operations and ensuring that production quality and quantity, environment, safety, health of people are maintained. We are also committed to increase the renewable energy share of the total energy we use.

We are also committed to monitor continuously the saving achieved and reduce its specific energy consumption by minimum of 2% every year.

Date -----

Head of the Institution

7.1. Energy management monitoring system

- **Energy Management Cell** has to be constituted with an objective to revise action plan for energy conservation thereby reducing the production cost.
- Energy conservation tips/ posters are displayed in crucial points.
- Use of renewable energy has to be encouraged.
- Flow meters and energy meters shall be installed in all major pumps. The meter reading shall be recorded in regular frequencies. It is recommended to install meters with communication capability to get real-time energy performance data and monitoring of pump performance.

7.2. Training to staff responsible for operational and Documentation.

- The staff need to be made more aware of the importance of energy saving and management.
- Log books shall be maintained to record Electricity Consumption and Diesel consumption.
- TOD reading shall be taken and compared with KSEB regularly.

7.3. Renewable Energy

- No renewable energy projects implemented.

This Page is Intentionally Kept Blank



Energy Conservation Measures and Recommendations



8.1. Electrical System

- Electrical safety measures have to be implemented.
- All the raw water pumps are operating 24hr a day, the scheduling may be done based on the performance test results given in the 5th chapter. The motors with combined efficiency near the design efficiency may be used for regular applications and the lowest performing pumps may be used as standby.
- As per the electrical load studies conducted the capacitance requirement in demand side (motor end) is 268 kVAR, which may cost around 1.2 lakhs Rs. For PF improvement. This will help increasing the PF to unity and will get incentives for the same. The demand will also come down due to better power factor.
- **FCMA** starters are used here which are harmonic free, rugged magnetic soft **starters** for motor starting. **FCMA** is an acronym for flux compensated magnetic amplifier which is basically a modulated inductive impedance. When connected in series with the motor the **FCMA** reduces the starting current to a low value. It is advised to switch all the starters to FCMA to save energy as well as to improve Switch gears & starters,
- Sub meters with communication facility shall be implemented for the effective monitoring of energy and water.
- Pumping machinery is subjected to wear & tear, erosion and corrosion due to its nature of functioning, and therefore it is vulnerable to failures. Generally, failures or interruptions are mostly attributed to pumping machinery rather than any other component. Therefore, correct operation and timely maintenance and upkeep of pumping stations and pumping machinery are of vital importance. Sudden failures can be avoided by timely inspection, follow up actions on observations of inspection and planned periodical maintenance. Downtime can be reduced by maintaining inventory of fast-moving spare parts. Obviously due attention needs to be paid to all such aspects for efficient and reliable functioning of pumping machinery.



OTTOTRACTIONS- ENERGY AUDIT	
Energy Saving Proposal Code EA 581.01	
Energy Saving in Lighting by replacing existing 28 No's T8 Lamps to 18W LED Tube	
Existing Scenario	
There are 28 numbers of T8 lamps installed in this facility. During discussion with officers it is observed that the average utility of these fittings are of 80%.	
Proposed System	
The existing T8 may be replaced to LED tube of 18 W in phased manner and the savings will be of 67 % (inclusive of improved light output and reduced energy consumption)	
Financial Analysis	
Annual working hours (hr)	6570
No of fittings	28
Total load (kW)	1.26
Annual Energy Consumption (kWh)	6623
Expected Annual Energy saving for replacing all fittings (kWh)	3642
Cost of Power	7.28
Annual saving in Lakhs Rs (1st year)	0.27
Investment required for complete replacements [@Rs 350 per fittings](Lakhs Rs)	0.10
Simple Pay Back (in Months)	4.43

Energy Saving Calculation						
Energy Efficiency in Existing Pumping system by replacing inefficient motor (RWPH HT 2)						
Sl No		Description	Unit	Existing System	New System	
Design Parameters	Motors	1	Total number of motors to be replaced	1	Standard	IE2
		2	Rated load of the motor	kW	400	330
		3	Efficiency of standard motor	%	94	95
		4	Type of Motor		Standard	IE2
		5	Motor power	kW	359.00	197.60
		6	Efficiency	%	85	95
		7	Combined efficiency of the system (rated)	%	79.9	90
		8	Combined efficiency of the system (measured)	%	50	90
	Input	9	Head	m	29	29
		10	Flow	m ³ /s	0.627	0.627
		11	Density of water	kg/m ³	1000	1000
		12	Gravitational Constant	m/s ²	9.81	9.81
		13	Hydraulic Power	kW	178.38	178.38
	14	Total Electrical Power drawn	kW	359.00	197.60	
	15	Unit Cost	Rs./kWh	7.28	7.28	
	16	Annual operating Hours	Hours	8760	8760	
	17	Annual energy consumption	kWh/year	3144840	1730976	
	18	Annual power Savings, kWh	kWh		1413864	
	19	Annual Savings	Rs. In Lakhs		102.93	
	20	Investment for Pumps (as per KWA guideline @15525 per hp)	Rs/kW		20500	
	21	Proposed pump load	kW		330.00	
	22	Investment	Rs. In Lakhs		67.65	
	23	Simple Payback period	Months		7.89	

Energy Saving Calculation						
Energy Efficiency in Existing Pumping system by replacing inefficient motor (RWPH HT 3)						
Sl No		Description	Unit	Old System	New System	
Design Parameters	Motors	1	Total number of motors to be replaced	1	Standard	IE2
		2	Rated load of the motor	kW	400	330
		3	Efficiency of standard motor	%	94	95
		4	Type of Motor		Standard	IE2
		5	Motor power	kW	346.00	195.70
		6	Efficiency	%	85	95
		7	Combined efficiency of the system (rated)	%	80	90.25
		8	Combined efficiency of the system (measured)	%	51	90.25
		9	Head	m	28.9	28.9
		10	Flow	m³/s	0.623	0.623
		11	Density of water	kg/m³	1000	1000
		12	Gravitational Constant	m/s²	9.81	9.81
		13	Hydraulic Power	kW	176.63	176.63
	Input	14	Total Electrical Power drawn	kW	346.00	195.70
		15	Unit Cost	Rs./kWh	6	6
		16	Annual operating Hours	Hours	8760	8760
		17	Annual energy consumption	kWh/year	3030960	1714332
		18	Annual power Savings, kWh	kWh		1316628
		19	Annual Savings	Rs. In Lakhs		79.00
		20	Investment for Pumps (as per KWA guideline @15525 per hp)	Rs/kW		20500
		21	Proposed pump load	kW		330.00
		22	Investment	Rs. In Lakhs		67.65
		23	Simple Payback period	Months		10.28

Energy Saving Calculation						
Energy Efficiency in Existing Pumping system by replacing inefficient motor (RWPH HT 4)						
Sl No		Description	Unit	Old System	New System	
Design Parameters	Motors	1	Total number of motors to be replaced	1	Standard	IE2
		2	Rated load of the motor	kW	400	330
		3	Efficiency of standard motor	%	94	95
		4	Type of Motor		Standard	IE2
		5	Motor power	kW	365.00	195.70
		6	Efficiency	%	85	95
		7	Combined efficiency of the system (rated)	%	80	90.25
		8	Combined efficiency of the system (measured)	%	48	90.25
		9	Head	m	28.9	28.9
		10	Flow	m³/s	0.623	0.623
		11	Density of water	kg/m³	1000	1000
		12	Gravitational Constant	m/s²	9.81	9.81
		13	Hydraulic Power	kW	176.63	176.63
	Input	14	Total Electrical Power drawn	kW	365.00	195.70
		15	Unit Cost	Rs./kWh	6	6
		16	Annual operating Hours	Hours	8760	8760
		17	Annual energy consumption	kWh/year	3197400	1714332
		18	Annual power Savings, kWh	kWh		1483068
		19	Annual Savings	Rs. In Lakhs		88.98
		20	Investment for Pumps (as per KWA guideline @15525 per hp)	Rs/kW		20500
		21	Proposed pump load	kW		330.00
22	Investment	Rs. In Lakhs		67.65		
23	Simple Payback period	Months		9.12		



OTTOTRACTIONS- ENERGY AUDIT						
KWA RAW WATER PUMPING STATION, PIRAVAM						
Greenhouse Gas Mitigation through Major Energy Efficiency Projects						
Sl No	Projects	Energy saved(Yearly)		Sustainability (Years)	First year ton of CO2 mitigated	Expected Tons of CO2 mitigated through out life cycle
		(kWh)	MWh	Years		
1	Energy Saving in Lighting by replacing existing 28 No's T12 Lamps to 18W LED Tube	6623	6.62	10	4.83	48.34
2	Energy Efficiency in Existing Pumping system by replacing inefficient motor (RWPH HT 2)	1413864	1413.86	10	1032.12	10321.21
3	Energy Efficiency in Existing Pumping system by replacing inefficient motor (RWPH HT 3)	1316628	1316.63	10	961.14	9611.38
4	Energy Efficiency in Existing Pumping system by replacing inefficient motor (RWPH HT 4)	1483068	1483.07	10	1082.64	10826.40
		4220182.56	4220.18	10.00	3080.73	30807.33

Implementation Schedule			
KWA RAW WATER PUMPING STATION, PIRAVAM			
Sl No	Projects	SPB	Implementation Schedule
1	Energy Saving in Lighting by replacing existing 28 No's T12 Lamps to 18W LED Tube	4.43	Medium Term
2	Energy Efficiency in Existing Pumping system by replacing inefficient motor (RWPH HT 2)	7.89	Medium Term
3	Energy Efficiency in Existing Pumping system by replacing inefficient motor (RWPH HT 3)	10.28	Medium Term
4	Energy Efficiency in Existing Pumping system by replacing inefficient motor (RWPH HT 4)	9.12	Medium Term

This Page is Intentionally Kept Blank

9

Technical Supplement





Electricity Bill Details (2018-2019)													
Month	Name of the Consumer				KERALA WATER AUTHORITY, KWA, JICA, CHERTHALA								
	Contract demnad (kVA)		921		Consumer number & Section				1355970011349				
	Tariff		HT I (A) INDUSTRIAL						Piravam				
	kWh				kVA				PF	PF Penalty / Incentive	Cost (Rs)	Cost in Lakhs Rs	Rs/kwh
Z1	Z2	Z3	Total	Z1	Z2	Z3	Max						
Apr	147280	49600	99770	296650	411	428	425	428	0.52	619998.5	2495954.75	24.96	8.41
May	107700	37130	76660	221490	428	427	423	428	0.97	-42658	1411142	14.11	6.37
Jun	95820	29980	62340	188140	428	427	423	428	0.97	-36216	1229370.55	12.29	6.53
Jul	138430	48190	90970	277590	429	426	426	429	0.97	-53436	1715307	17.15	6.18
Aug	133090	45000	84600	262690	431	425	427	431	0.97	-50567	1634363	16.34	6.22
Sep	125120	41430	77360	243910	426	421	425	426	0.97	-34602	2696848	26.97	11.06
Oct	136910	47420	90590	274920	426	425	423	426	0.97	-52922.1	1742040.9	17.42	6.34
Nov	139820	47520	93330	280670	426	423	422	426	0.97	-54028	1774140.28	17.74	6.32
Dec	132150	41570	162570	336290	424	424	422	424	0.90	0	2149374.75	21.49	6.39
Jan	137380	49380	17770	204530	426	427	421	427	0.70	224983	1582764.25	15.83	7.74
Feb	140620	48670	92980	282270	428	422	422	428	0.97	-54336.97	1740732	17.41	6.17
Mar	119170	39940	79890	239000	424	423	426	424	0.94	-39652.8	2297347	22.97	9.61
				3108150	5106	5098	5083		0.90		22469384.3		7.28



Time	Incomer		Pump IV					Power Factor	KWH	UNITS/HRS
	KV	HZ	KV	A	PR	WT.	BT.			
1.00	11.01	50.10	3.3	65	2.89	95.6	62.7	0.974	2136933	41
2.00	11.05	50.06	3.3	65	2.89	95.9	63.3	0.974	2136975	42
3.00	11.03	50.09	3.3	65	2.89	96.1	63.8	0.974	2137015	40
4.00	10.99	50.03	3.3	65	2.89	96.3	64.1	0.974	2137056	41
5.00	10.95	50.05	3.3	65	2.89	96.7	64.5	0.973	2137096	40
6.00	10.92	50.01	3.3	65	2.89	96.8	64.7	0.972	2137136	40
7.00	10.84	50.00	3.3	65	2.89	96.9	64.5	0.972	2137178	42
8.00	10.76	49.99	3.3	65	2.89	97.3	63.7	0.97	2137218	40
9.00	10.71	49.97	3.3	65	2.89	97.6	63.2	0.969	2137258	40
10.00	10.68	49.95	3.3	65	2.89	98.3	63.8	0.97	2137300	42
11.00	10.78	49.89	3.3	65	2.89	98.9	64.6	0.97	2137342	42
12.00	10.77	50.07	3.3	65	2.89	99.6	65.1	0.972	2137383	41
13.00	10.79	49.99	3.3	65	2.89	100.3	66.1	0.973	2137424	41
14.00	10.84	50.13	3.3	65	2.89	100.7	64.4	0.975	2137467	43
15.00	10.69	50.02	3.3	65	2.89	101.2	64.7	0.973	2137509	42
16.00	10.77	49.95	3.3	65	2.88	101.4	66.6	0.973	2137547	38
17.00	10.62	50.02	3.3	65	2.89	101.5	66.4	0.973	2137589	42
18.00	10.68	50.01	3.3	65	2.88	101.4	65.9	0.972	2137631	42
19.00	10.75	50.04	3.3	65	2.88	101.2	65.6	0.975	2137673	42
20.00	10.76	50.02	3.3	65	2.89	100.9	65.3	0.974	2137712	34
21.00	10.77	49.96	3.3	65	2.89	100.1	64.4	0.975	2137754	42
22.00	10.94	50.03	3.3	65	2.90	99.3	63.9	0.974	2137743	39
23.00	10.97	50.07	3.3	65	2.91	98.7	63	0.973	2137832	39
24.00	11.00	50.02	3.3	65	2.91	98.6	62.9	0.973	2137870	38



Time	Incomer		Pump IV					Power Factor	KWH	UNITS/HRS
	KV	HZ	KV	A	PR	WT.	BT.			
1.00	11.02	50.07	3.3	65	2.91	98.3	62.6	0.972	2137912	42
2.00	11.04	49.90	3.3	65	2.91	98.0	62.5	0.971	2137954	42
3.00	11.07	50.06	3.3	65	2.91	97.9	61.9	0.972	2137994	40
4.00	11.02	50.02	3.3	65	2.91	97.2	61.7	0.977	2138032	38
5.00	11.05	49.99	3.3	65	2.91	96.7	61	0.977	2138070	38
6.00	10.94	49.92	3.3	65	2.91	96.5	61.2	0.973	2138108	38
7.00	10.92	49.98	3.3	65	2.91	96.3	61	0.971	2138146	38
8.00	10.86	50.00	3.3	65	2.91	96.2	62	0.972	2138188	42
9.00	10.66	50.02	3.3	65	2.91	97.6	62	0.973	2138232	43
10.00										
11.00	10.45	50.07	3.3	65	2.91	93.4	64.5	0.971	2138291	60
12.00	10.83	49.94	3.3	65	2.92	94.2	65.7	0.973	2138333	42
13.00										
14.00	11.08	50.09	3.3	65	2.9	92.4	66	0.971	2138374	
15.00	10.93	50.01	3.3	65	2.9	92.7	66.3	0.973	2138414	40
16.00	10.9	50.05	3.3	65	2.89	97.7	66.5	0.971	2138454	40
17.00	10.89	50.00	3.3	65	2.89	98.3	66.7	0.971	2138494	40
18.00	10.93	50.03	3.3	65	2.89	99	66.8	0.974	2138535	41
19.00	10.95	50.06	3.3	65	2.89	99.7	66.5	0.974	2138575	40
20.00	10.97	50.04	3.3	65	2.89	100.2	66.4	0.974	2138615	40
21.00	10.79	50.01	3.3	65	2.91	100	66	0.971	2138655	40
22.00										
23.00	10.7	50.05	3.3	65	2.92	94.1	64.3	0.974	2138706	51
24.00	10.72	50.05	3.3	65	2.93	95.0	63.5	0.974	2138745	39



Time	Incomer		Pump IV					Power Factor	KWH	UNITS/HRS
	KV	HZ	KV	A	PR	WT.	BT.			
1.00	10.89	50.01	3.3	65	2.93	95.6	63.3	0.970	2138745	42
2.00	10.91	49.97	3.3	65	2.93	95.8	63.1	0.971	2138826	39
3.00	10.92	50.00	3.3	65	2.93	96.2	62.9	0.971	2138869	43
4.00	10.87	49.98	3.3	65	2.93	96.3	62.7	0.971	2138907	38
5.00	10.8	49.91	3.3	65	2.93	96.1	62.6	0.97	2138949	42
6.00	10.76	49.94	3.3	65	2.93	96	62.6	0.973	2138989	40
7.00	10.54	50.01	3.3	65	2.93	96.1	62.9	0.972	2139031	42
8.00	10.55	49.97	3.3	65	2.93	96.3	63.4	0.972	2139070	39
9.00	10.57	49.98	3.3	65	2.93	96.8	64.1	0.972	2139113	43
10.00	10.63	50.08	3.3	65	2.93	97.5	64.9	0.974	2139152	39
11.00	10.81	50.02	3.3	65	2.92	98.2	65.4	0.973	2139194	42
12.00	10.78	50.06	3.3	65	2.92	99.4	66.6	0.971	2139234	40
13.00	11.06	50.06	3.3	65	2.92	100.4	67.2	0.972	2139277	43
14.00	10.85	49.95	3.3	65	2.91	101.4	67.9	0.973	2139320	43
15.00	10.84	50.04	3.3	65	2.91	102.2	68.4	0.973	2139360	40
16.00	10.87	49.96	3.3	65	2.91	102.2	68	0.972	2139400	40
17.00	10.91	50.04	3.3	65	2.91	102.1	67.9	0.972	2139440	40
18.00	11.08	50.10	3.3	65	2.91	102	67.6	0.974	2139482	42
19.00	10.64	50.07	3.3	65	2.91	101.8	67	0.974	2139521	39
20.00	10.87	50.03	3.3	65	2.92	100.9	66.1	0.975	2139563	42
21.00	10.92	49.98	3.3	65	2.92	100.5	65.8	0.973	2139606	43
22.00	10.91	50.01	3.3	65	2.92	99.5	65.2	0.973	2139648	42
23.00										
24.00	10.88	49.91	3.3	65	2.93	90.7	66.9	0.974	2139686	38




Time	Incomer		Pump IV					Power Factor	KWH	UNITS/HRS
	KV	HZ	KV	A	PR	WT.	BT.			
1.00	10.8	50.07	3.3	65	2.92	92.6	67.4	0.923	2139727	41
2.00	10.69	50.01	3.3	65	2.92	94	67.5	0.972	2139767	40
3.00	10.75	50.03	3.3	65	2.92	94.2	65	0.972	2139807	40
4.00	10.64	50.11	3.3	65	2.92	93.7	64.3	0.921	2139846	39
5.00	10.7	50.05	3.3	65	2.92	93	63.4	0.973	2139888	42
6.00	10.78	50.07	3.3	65	2.92	93.5	62.7	0.973	2139929	41
7.00	10.74	50.07	3.3	65	2.92	94.7	63.1	0.974	2139967	38
8.00	10.73	50.04	3.3	65	2.92	95.5	63.6	0.972	2140005	38
9.00	10.75	50.05	3.3	65	2.92	96.9	64	0.973	2140044	39
10.00	10.79	50.02	3.3	65	2.92	97.7	64.9	0.972	2140094	40
11.00	10.69	50.05	3.3	65	2.92	98.9	65.9	0.971	2140137	43
12.00	10.8	50.09	3.3	65	2.91	94.9	66.8	0.974	2140176	39
13.00	11.05	50.11	3.3	65	2.92	100.6	67.5	0.974	2140218	42
14.00										





Time	Incomer		Pump II					Power Factor	KWH	UNITS/HRS
	KV	HZ	KV	A	PR	WT.	BT.			
1.00	11.02	50.02	3.3	65	2.89	92.1	65.7	0.970	2106446	40
2.00	11.01	49.91	3.3	65	2.89	91.5	65	0.973	2106484	38
3.00	10.89	50.00	3.3	65	2.89	90.4	64.3	0.971	2106525	41
4.00	10.91	50.01	3.3	65	2.88	90.2	64	0.971	2106565	40
5.00	10.94	49.97	3.3	65	2.89	90.9	64.7	0.971	2106605	40
6.00	10.95	49.92	3.3	65	2.89	91.4	65.1	0.97	2106646	41
7.00	10.91	49.95	3.3	65	2.89	91.5	65.1	0.971	2106687	41
8.00	10.89	49.91	3.3	65	2.88	91.7	64.2	0.972	2106727	40
9.00	10.97	49.98	3.3	65	2.88	92	64	0.97	2106767	40
10.00	10.9	50.00	3.3	65	2.88	92.3	63.1	0.972	2106808	41
11.00	10.91	49.99	3.3	65	2.88	92.5	61.4	0.971	2106849	41
12.00	11.03	50.04	3.3	65	2.88	93.1	65.2	0.971	2106889	40
13.00	11.08	50.06	3.3	65	2.88	94.4	64.1	0.972	2106930	41
14.00	10.86	49.92	3.3	65	2.88	95.7	70.1	0.970	2106970	40
15.00	10.88	49.95	3.3	65	2.88	96	70.5	0.970	2107010	40
16.00	10.92	49.97	3.3	65	2.88	96.3	71	0.970	2107050	40
17.00	10.94	50.00	3.3	65	2.88	96.5	70.5	0.970	2107090	40
18.00	10.95	50.01	3.3	65	2.88	96	70.1	0.971	2107128	38
19.00	10.9	50.03	3.3	65	2.88	95.5	69	0.971	2107168	40
20.00	10.93	50.05	3.3	65	2.88	95.1	68.2	0.971	2107207	39
21.00	10.99	50.06	3.3	65	2.88	94.3	67.7	0.971	2107298	41
22.00	10.92	50.13	3.3	65	2.88	93.5	67	0.97	2107290	42
23.00	11.02	50.02	3.3	65	2.87	93	66.6	0.971	2107332	42
24.00	11.14	50.03	3.3	65	2.87	92.3	66.1	0.971	2107334	42


2020/01/22 14:24:00 - 2020/01/22 14:45:00





2020/01/22 14:24:00 - 2020/01/22 14:45:00




















2020/01/22 14:24:00 - 2020/01/22 14:45:00



2020/01/22 14:24:00 - 2020/01/22 14:45:00




2020/01/22 14:24:00 - 2020/01/22 14:45:00




2020/01/22 14:24:00 - 2020/01/22 14:45:00

0.005MVA/div CHsum MIN CHsum MAX CHsum AVE

S[VA]
CHsum




2020/01/22 14:24:00 - 2020/01/22 14:45:00



2020/01/22 14:24:00 - 2020/01/22 14:45:00


0.100 /div CHsum MIN CHsum MAX CHsum AVE




2020/01/22 14:24:00 - 2020/01/22 14:45:00

0.4 %/div CH1 MIN CH1 MAX CH1 AVE


U unb[%]




2020/01/22 14:24:00 - 2020/01/22 14:45:00



2020/01/22 14:24:00 - 2020/01/22 14:45:00




2020/01/22 14:24:00 - 2020/01/22 14:45:00



2020/01/22 14:45:00 - 2020/01/22 15:00:00 Demand Interval:15Minute


MAX demand value: 3.147kW 01/22 14:45:00 AVE demand value: 3.147kW
Load factor: 100.0%



2020/01/22 14:45:00 - 2020/01/22 15:00:00 Demand Interval:15Minute

MAX demand value: 000.0mW 01/22 14:45:00 AVE demand value: 000.0mW

Load factor: ----- %



OTTOTRACTIONS

Demand Analysis


02-11-2020 D:\OT ABIN AUG 2019\Ongoing\EA\KWA HT\EA 584 PH PIRAVAMB0012300

Measurement from a HIOKI 3197 PQA

KWA Piravom

2020/01/22 14:45:00 - 2020/01/22 15:00:00 Demand Interval:15Minute

MAX demand value: 5.674kvar 01/22 14:45:00 AVE demand value: 5.674kvar
Load factor: ----- %



OTTOTRACTIONS

Demand Analysis

02-11-2020 D:\OT ABIN AUG 2019\Ongoing\EA\KWA HT\EA 584 PH PIRAVAMB0012300

Measurement from a HIOKI 3197 PQA

KWA Piravom

2020/01/22 14:45:00 - 2020/01/22 15:00:00 Demand Interval:15Minute


MAX demand value: 000.0mvar 01/22 14:45:00 AVE demand value: 000.0mvar
Load factor: ----- %



2020/01/22 14:24:00 - 2020/01/22 14:45:00

Maximum integrated power value: 1.0899kWh


0.2500kWh/div



2020/01/22 14:24:00 - 2020/01/22 14:45:00

Maximum integrated power value: 0.0000 Wh


0.2000 Wh/div



2020/01/22 14:24:00 - 2020/01/22 14:45:00

Maximum integrated power value: 2.0181kvarh

0.5000kvarh/div




2020/01/22 14:24:00 - 2020/01/22 14:45:00


Maximum integrated power value: 0.0000 varh


0.2000 varh/div

WQ LEAD[varh]



SINGLE LINE DIAGRAM







Enriching Lives



VERTICAL PUMPS


TYPE - BHR / BHQ / BHM / BHK
/ BHM_a / BHA



KIRLOSKAR BROTHERS LIMITED


A Kirloskar Group Company

FAMILY CURVES FOR BHR PUMPS (50HZ)



NOTE: FIGURES IN BRACKET INDICATE SPEED IN RPM


FAMILY CURVES FOR BHR PUMPS (60HZ)



NOTE: FIGURES IN BRACKET INDICATE SPEED IN RPM


FAMILY CURVES

FAMILY CURVES FOR BHQ PUMPS (50HZ)




NOTE: FIGURES IN BRACKET INDICATE SPEED IN RPM

FAMILY CURVES FOR BHQ PUMPS (60HZ)




NOTE: FIGURES IN BRACKET INDICATE SPEED IN RPM

FAMILY CURVES FOR BHM PUMPS (50HZ)




NOTE: FIGURES IN BRACKET INDICATE SPEED IN RPM

FAMILY CURVES FOR BHM PUMPS (60HZ)




NOTE: FIGURES IN BRACKET INDICATE SPEED IN RPM

FAMILY CURVES FOR BHM_a PUMPS (50HZ)



NOTE: FIGURES IN BRACKET INDICATE SPEED IN RPM

FAMILY CURVES FOR BHM_a PUMPS (60HZ)



NOTE: FIGURES IN BRACKET INDICATE SPEED IN RPM

ABOUT KBL

Kirloskar Brothers Limited (KBL) is a world class pump manufacturing company with expertise in engineering and manufacture of systems for fluid management. Established in 1888 and incorporated in 1920, KBL is the flagship company of the \$ 2.1 billion Kirloskar Group. KBL, a market leader, provides complete fluid management solutions for large infrastructure projects in the areas of water supply, power plants, irrigation, oil & gas and marine & defence. We engineer and manufacture industrial, agriculture and domestic pumps, valves and hydro turbines.

In 2003, KBL acquired SPP Pumps, United Kingdom and established SPP INC, Atlanta, USA, as a wholly owned subsidiary of SPP, UK to expand its international presence. In 2007, Kirloskar Brothers International B.V., The Netherlands and Kirloskar Brothers (Thailand) Ltd., a wholly owned subsidiary in Thailand, were incorporated. In 2008, KBL incorporated Kirloskar Brothers Europe B.V. (Kirloskar Pompen B.V. since June 2014), a joint venture between Kirloskar International B.V. and Industrial Pump Group, The Netherlands. In 2010, KBL further consolidated its global position by acquiring Braybar Pumps, South Africa. SPP MENA was established in Egypt in 2012. In 2014, KBL acquired SyncroFlo Inc., the largest independent fabricator of commercial and municipal domestic water booster pumps.

To further strengthen its global position, in 2015, Kirloskar Pompen B.V. acquired Rodelta Pumps International, The Netherlands.

KBL has joint venture cooperation with Ebara, Japan since 1988 for the manufacture of API 610 standard pumps. Kirloskar Corrocoat Private Limited is a joint venture cooperation with Corrocoat, UK since 2006. KBL acquired The Kolhapur Steel Limited in 2007 and Hematic Motors in 2010.

KBL has eight manufacturing facilities in India at Kirloskarvadi, Dewas, Kondhapuri, Shirwal, Sanand, Kaniyur, Kolhapur and Karad. In addition, KBL has global manufacturing and packaging facilities in Egypt, South Africa, Thailand, The Netherlands, United Arab Emirates, United Kingdom and United States of America. KBL has 12,700 channel partners in India and 80 overseas and is supported by best-in-class network of Authorised Centres and Authorised Refurbishment Centres across the country.

All the manufacturing facilities at KBL are certified for ISO 9001, ISO 14001, ISO 50001, BS OHSAS 18001 and SA8000. In addition, the Kirloskarvadi plant is also certified for N & NPT Stamp. KBL's corporate office in Pune is certified for ISO 9001 & Sa8000.

The factories deploy Total Quality Management tools using European Foundation for Quality Management (EFQM) model. The Kirloskarvadi plant of KBL is a state-of-the-art integrated manufacturing facility having Asia's largest hydraulic research centre with testing facility upto 5000 kW and 50,000 m³/hr.

KBL is the ninth pump manufacturing company in the world to be accredited with the N and NPT certification by American Society of Mechanical Engineers (ASME).

Pumps | Valves | Hydro Turbines | Turnkey Projects

Water Resource Management | Irrigation | Power | Industry | Oil & Gas | Marine & Defence | Building & Construction | |
Distribution (Small Pumps) | Valves | Customer Service & Spares

KIRLOSKAR BROTHERS LIMITED

A Kirloskar Group Company

Registered Office: Udyog Bhavan, Tilak Road , Pune 411002. Tel: +91(20)24440770
Global Headquarters: "Yamuna", Survey No. 98/(3.7), Baner, Pune 411045. Tel: +91(20)27214444
Email: marketing@kbl.co.in, Website: www.kirloskarpumps.com, CIN No.: L29113PN1920PLC000670

OUR COMPANIES



United Kingdom



U.S.A.



South Africa



India



The Netherlands



Jyoti Ltd.

Water • Power • Progress

JYOTI Vertical Turbine Pumps (oil & water-lubricated)



Manufactured, designed
and made the First Vertical Turbine
(VT) Pump in India, way back in 1942

ISO 9001:2015 || TUV INDIA



APPLICATION

Pumps for

- irrigation
- urban & rural water supply
- Cooling tower
- Fire fighting
- Flood control
- Mine dewatering
- Thermal power stations
- Condensate extraction
- General & process water in industries
- Oil field water services and a hoast of other needs.

RANGE

Bowl sizes	150 mm to 600 mm
Capacity	200 lpm to 33200 lpm
Head	upto 225 mts

For higher capacities refer to us.

SPECIAL DESIGN FEATURES

- Heavy wall cast iron bowls & cast iron / Stainless Steel impellers provided for maximum operating life, under arduous Indian conditions.
- Impeller shafts of stainless steel
- Column pipes and line shafts are machined and threaded on double ended special purpose machines in single setting ensuring concentricity.
- All shaft couplings in water lubricated pumps are made of stainless steel for extra-long life.

CONSTRUCTIONAL FEATURES

'JYOTI' VT pumps are offered in non-pull out construction as a standard design. The pump can be supplied for coupling with vertical hollow shaft motors or vertical solid shaft motors. Also for surface discharge or underground discharge.

BOWLS

Standard bowls are made of close grained cast iron. The diffuser vanes are cast integrally.

IMPELLERS

Impellers are closed or semi-open type, statically and dynamically balanced for vibration-free operation. They are secured to the impeller shaft with tapered lock collects or keys & split rings. The impeller position can be adjusted vertically by means of impeller-adjusting nut provided in the drive.

IMPELLER SHAFT

Impeller shaft is of stainless steel, accurately ground to close tolerances. The shaft is supported by bearings above and below each impeller.

COLUMN PIPES

Column pipes are normally supplied in nominal lengths of 3.0m, 1.5m and 0.75m pipes of non-standard lengths also can be supplied on request.

LINE SHAFTS

Line shafts are of high grade carbon steel, ground to close tolerances and threaded concentrically at the ends. Available in nominal lengths of 3.0m, 1.5m and 0.75m and in non-standard lengths to suit specific site conditions. Line shaft in stainless steel and suitable for muff couplings also can be supplied, if required.

LINE SHAFT BEARINGS

Made of bronze for oil lubricated pumps and Nitrile Rubber for water lubricated pumps.

SHAFT ENCLOSING TUBES

(for oil-lubricated pump)

These heavy duty steel tubes protect the line shafts from corrosion and foreign materials and support the line shaft bearings. The tubes are threaded concentrically in one setting at both ends. Available in different lengths, as line shafts.


DISCHARGE HEAD

Standard construction in cast iron. Fabricated ones also can be supplied on request. Pump can be supplied with surface or underground discharge to suit specific site conditions.

DRIVES

Electrical motors with vertical hollow shaft or vertical solid shaft are normally used. Alternatively right angle gear head with diesel engine also can be used.

FAMILY CURVE FOR STANDARD VT PUMPS (225 to 550 mm)



STANDARD MATERIAL OF CONSTRUCTION

OIL LUBRICATED / WATER LUBRICATED / FORCE LUBRICATED PUMP


S.NO.	PART DESCRIPTION	MATERIAL	SPECIFICATION
1	STAINER	M.S.	IS : 2062 St.42-S
2	SUCTION CASE	CAST IRON	IS : 210 Gr FG-200
3	SUCTION CASE BEARING	BRONZE	IS : 318 Gr LTB2
4	IMPELLER SEAL RING	CAST IRON	IS : 210 Gr FG-200
		BRONZE	IS : 318 Gr LTB2
5	IMPELLER	CAST IRON	IS : 210 Gr FG-200/260
		BRONZE	IS : 318 Gr LTB2
6	BOWL	CAST	IRON IS : 210 Gr FG-260
7	IMPELLER SHAFT	ST. STEEL	ASTM A276 SS 410
8	DISCHARGE CASE	CAST IRON	IS : 210 Gr FG-200/260
9	COLUMN PIPE ADOPTOR	CAST IRON	IS : 210 Gr FG-200/260
10	GUIDE SPIDER/BEARING HOLDER	CAST IRON	IS : 210 Gr FG-200/260
11	COLUMN PIPE	ERW STEEL	IS : 1239 Class C / IS : 1978
		M.S. FABRICATED	IS : 2062 St.42-S
12	SHAFT ENCLOSING TUBE (OL)	STEEL	IS : 1239 Class C / IS : 1978
13	LINE SHAFT CARBON	STEEL	IS : 1570 C40 / ASTM A276 SS 410
14	LINE SHAFT COUPLING (OL) CARBON	STEEL	IS : 1570 C40 / ASTM A276 SS 410
15	LINE SHAFT COUPLING (WL) ST.	STEEL	ASTM A276 SS 410
16	LINE SHAFT BEARING (OL)	BRONZE	IS : 318 Gr LTB2
17	LINE SHAFT BEARING (WL)	NITRILE RUBBER	SHORE HARDNESS 60-65
18	TOP COLUMN FLANGE	CAST IRON	IS : 210 Gr FG-200/260
19	DISCHARGE HEAD BODY	CAST IRON	IS : 210 Gr FG-200/260
		M.S. FABRICATED	IS : 2062 St.42-S
20	HEAD SHAFT CARBON	STEEL	IS : 1570 C40 / ASTM A276 SS 410
21	STUFFING BOX	CAST IRON	IS : 210 Gr FG-200/260
22	GLAND	CAST IRON	IS : 210 Gr FG-200/260
23	MOTOR SKIRT	CAST IRON	IS : 210 Gr FG-200/260
		M.S. FABRICATED	IS : 2062 St.42-S
24	MOTOR	VERTICAL HOLLOW OR SOLID SHAFT	IS : 325

NOTE : Material of Construction mentioned above are our standard ones, other materials to suit specific site conditions can be supplied on request.

OPTIONAL ACCESSORIES


- Foundation bolts
- Sole plate
- Companion flanges.

'JYOTI' VERTICAL TURBINE PUMP (WATER-LUBRICATED)



Sr. No.	PART NAME
46	Vertical Hollow Shaft Motor
45	Adapting Plate or Distance Piece
44	Valve
43	Water Lubricating Tube
42	Water Leakage Tube
41	Water Deflector
40	Lantern Ring
39	Gland Packing
38	Gland Packing Ring
37	Gland
36	Stuffing Box Gasket
35	Stuffing Box Bush
34	Stuffing Box
33	Discharge Head Body
32	Stilling Pipe
31	Delivery Flange Gasket
30	Delivery Flange (Up to D-150 Dis-Head)
29	Head Shaft Coupling
28	Head Shaft
27	Top Column Flange Gasket
26	Top Column Flange - Flanged or Threaded
25	Column Pipe Coupling Threaded
24	Line Shaft Coupling
23	Rubber Bearing
22	Brg. Holder Flanged or Threaded
21	Line Shaft
20	Column Pipe flanged or Threaded
19	Col. Pipe flanged or Threaded or Threaded
18	Impeller Shaft Coupling
17	Impeller Shaft
16	Top Bowl
15	Bowl Bearing
14	Bowl
13	Impeller Collet Nut washer
12	Impeller Collet Nut
11	Impeller Collet
10	Circlip
9	Impeller Key
8	Impeller
7	Impeller Holding Split Ring
6	Impeller Seal Ring
5	Suction Case Sand Collar
4	Suction Case Bearing
3	Suction Case
2	Suction Case Plug
1	Suction pipe Strainer

FOUNDATION DRAWING for 'JYOTI' VERTICAL TURBINE PUMP.



Discharge Head													Foundation		
	A	B	C	D	E	F	G	H	K	L	M	N	Dia	No.	Length
D/DS 100	600	400	335	260	295	460	156	30	190	4	18	178	M 16	4	250
D/DS 150	640	440	375	295	330	460	203	35	215	8	18	235	M 20	4	300
D/DS 200	775	565	485	410	410	610	235	45	285	8	18	292	M 24	4	500
D/DS 250	900	690	600	500	520	610	270	60	350	8	22	356	M 24	4	500
D/DS 300	900	700	600	500	520	610	320	60	355	12	22	406	M 24	4	500
D/DS 350	1050	850	740	625	590	700	365	60	430	12	24	470	M 24	4	500
D/DS 400	1050	850	740	625	590	700	380	60	430	12	24	521	M 24	4	500

All dimensions are in mm except otherwise stated.

Note : Delivery flanges are according to BS : 10, Table "E"



FOR FURTHER ENQUIRIES PLEASE CONTACT BRANCH OFFICES

PUMP DIVISION
 Nanubhai Amin Marg, Industrial Area,
 P.O. Chemicals Industries,
 Vadodara-390 003 (India).
 Phones : +91-265-3054444
 Fax : +91-265-2281871
 2280671
 E-mail : pumps@jyoti.com
 Website : www.jyoti.com

Bangalore : 35/3, 2nd Floor, Novelty Mansion, 2nd Cross, IV Block, Kumarapark West, Bangalore-560 020. Telefax : 080-23562248 E-mail : bangalore@jyoti.com
Chennai : VEE DEE YEM Complex, 1st Floor, 270, Lloyds Road, Royapettah, Chennai 600014, Ph. : 044-28131754, Fax : 044-28133178, E-mail : chennai@jyoti.com
Indore : E-mail : indore@jyoti.com (Resident Representative (M) 09303211776
Kolkata : 45, Jhowtalla Road, Syed Amir Ali Avenue, Kolkata-700 019, Ph. : 033-22902056, Fax : 033-22875267, E-mail : kolkata@jyoti.com
Mumbai : Narsinh Sadan, Flat No. 102, 1st Floor, 1st Road, Golibar, Santacruz (East), Mumbai-400 055. Ph. : 022-26134403 (D), 26122848, E-mail : mumbai@jyoti.com
New Delhi : 7, Jantar Mantar Road, New Delhi-110 001. Ph. : 011-23340576, E-mail : delhi@jyoti.com
Secundrabad : 5-4-187/7, 1st Floor, Karbala Maidan, M. G. Road, Secundrabad-500 003. Ph. : 040-27544587 (D), 2754708 Fax : 040-27543673, E-mail : jyotisecc@jyoti.com

In keeping with the technological strides the world is making in the engineering field, we introduce changes in the design of our products. Hence, the products as actually supplied might have features varying here from.
The word 'Jyoti' and 'Jyoti' logo are the registered trademarks of Jyoti Ltd. Vadodara.

This Page is Intentionally Kept Blank