



Approved by Kerala State Pollution Control Board

**TEST REPORT**

Test Report No : WCL/TCR/2020/4920

Date : 5/10/2021

Customer Name & Address : M/S.Sainath envirotech STP plant,Trivandrum medical college,Trivandrum

Date of sample collection : 28/09/2021

Date of start of analysis : 28/09/2021

Type of Sample : STP treated water

Date of Completion of analysis : 5/10/2021

Sample Drawn by : The customer

Test Results					
Sl. No	PARAMETERS	METHOD OF ANALYSIS	UNIT	TOLERANCE LIMIT (KSPCB)	RESULT
1.	pH	IS 3025 : 1983	-	5.5 - 9.0	6.3
2.	Total Suspended solids	IS 3025 : 1984	mg/L	100	84
3.	BOD	IS 3025 : 1993	mg/L	30	28.6
4.	COD	IS 3025 : 2006	mg/L	250	148
5.	Oil and grease	IS 3025 : 1989	mg/L	10	3.2

Remarks: From the analysis, all the parameters are within the acceptable limit.

FOR WATER CARE LABORATORIES



Note: The above results are related only to the sample submitted for the analysis. This test report shall not be reproduced expect in full, without the written approval of the laboratory