



Approved by Kerala State Pollution Control Board

**TEST REPORT**

Test Report No : WCL/TCR/2021/4609

Date : 24/08/2021

Customer Name & Address : M/s. Sainath EnviroTech , Trivandrum medical college campus , Ulloor

Date of sample collection : 13/08/2021

Date of start of analysis : 13/08/2021

Type of Sample : STP Treated water

Date of Completion of analysis : 24/08/2021

Sample Drawn by : The customer

Test Results					
Sl. No	PARAMETERS	METHOD OF ANALYSIS	UNIT	TOLERANCE LIMIT (KSPCB)	RESULT
1.	pH	IS 3025 : 1983	-	5.5 - 9.0	6.2
2.	Total Suspended Solids	IS 3025 : 1984	mg/L	<100	126
3.	BOD	IS 3025 : 1993	mg/L	< 30	28.6
4.	COD	IS 3025 : 2006	mg/L	<250	128
5.	Oil and grease	IS 3025 : 1989	mg/L	<10	4.6

Remarks: From the analysis, Total Suspended Solids is not within the limit.



FOR WATER CARE LABORATORIES

Authorized Signatory

*Deepu*  
24/08/21

Note: The above results are related only to the sample submitted for the analysis. This test report shall not be reproduced except in full, without the written approval of the laboratory