



Approved by Kerala State Pollution Control Board

## TEST REPORT

Test Report No : WCL/TCR/2021/4617

Date : 26/08/2021

Customer Name & Address : M/s. Sainath Envirotech , Trivandrum Medical college campus, Ulloor

Date of sample collection : 18/08/2021

Date of start of analysis : 18/08/2021

Type of Sample : STP Treated Water

Date of Completion of analysis : 25/08/20201

Sample Drawn by : The customer

### Test Results

Sl. No	PARAMETERS	METHOD OF ANALYSIS	UNIT	TOLERANCE LIMIT (KSPCB)	RESULT
1.	pH	IS 3025 : 1983	-	5.5 - 9.0	6.1
2.	Total Suspended Solids	IS 3025 : 1984	mg/L	< 100	78
3.	BOD	IS 3025 : 1993	mg/L	< 30	8.6
4.	COD	IS 3025 : 2006	mg/L	< 250	31
5.	Oil and grease	IS 3025 : 1989	mg/L	≤ 10	2.4

Remarks: From the analysis all the tested parameters are within the limit.



FOR WATER CARE LABORATORIES

Authorized Signatory

*Deepu*  
26/08/21