



**REPORT ON ENERGY AUDIT OF 73 MLD WTP AT  
PANAMKUTTYMALA UNDER KOTTARAKKARA DIVISION, KWA**



**TEAM ENERGY AUDIT, KWA NOVEMBER 2021**



## **ACKNOWLEDGMENT**

We, the team members take this opportunity to express our sincere gratitude to Sri. Venkiteshpathy.S, IAS, MD KWA, who entrusted this assignment and gave timely directions to complete the audit as per schedule. We at KWA consider his leadership and inspiration a privilege.

We would like to express our thanks to Smt. SINDHU J S, AEE, PH Subdivision, Valakom, and Smt. Haisal Harison, AE HW Section, Panamkuttymala, who is in charge of this plant. We also thank all the staff of HW Section, Panamkuttymala, especially the operating staff at the water treatment plant.

We do not have any hesitation that to say, there are very many initiatives is shown from the operations wing at HO to address the energy issues faced by KWA, under the leadership of CE operations and his team. We take the privilege to express our gratitude to them.

As the team leader, I would like to express my gratitude to Sri. Manoj M, EE Sulthan Bathery and Smt. Sreelatha B.V, EE Kollam, who kindly spared their team members so that we could finish the audit on time.



## TABLE OF CONTENTS

<b>ACKNOWLEDGEMENT</b>	2
<b>EXECUTIVE SUMMARY</b>	5
<b>CHAPTER 1</b>	
1 INTRODUCTION	1
1.1 VISION	2
1.2 MISSION	2
1.3 SLOGAN	2
1.4 SCOPE	2
1.5 ENERGY AUDIT TEAM	2
1.6 ABOUT THE ENERGY AUDIT TEAM, KWA	3
1.7 MAJOR ACTIVITIES OF ENERGY AUDIT TEAM, KWA	3
1.8 METHODOLOGY	3
<b>CHAPTER 2</b>	
2 WTP PANAMKUTTYMALA	5
2.1 SOURCE	5
2.2 WORKS CAPACITY	5
2.3 RAW WATER QUALITY	6
2.3.1 RESULTS OF RAW WATER ANALYSIS	6
<b>CHAPTER 3</b>	
3 WATER TREATMENT PROCESS	9
3.1 TREATED WATER QUALITY CRITERIA (LIMITING VALUES)	10
3.2 INLET WORKS	12
3.3 MIXING FLUME	12
3.4 CLARIFLOCCULATION	12
3.5 RAPID GRAVITY FILTERS	12
3.6 WASH WATER REUSE	13
<b>CHAPTER 4</b>	
4 CONTROL AND MONITORING SYSTEMS	13
<b>CHAPTER 5</b>	
5 WATER FLOW DIAGRAMS AND PHOTOS	14
5.1 WATER FLOW DIAGRAMS AND PHOTOS	14
5.2 AERATOR	15
5.3 LAMELLAE CLARIFIER	15
5.4 CLEAR WATER PUMP HOUSE	16
5.5 PRELIMINARY TREATED WATER PUMPING PLANT DRAWING(A)	17
5.6 PRELIMINARY TREATED WATER PUMPING PLANT DRAWING(B)	17
5.7 TREATED WATER SYSTEM FLOW/HEAD CURVES	18
5.8 BACKWASH WATER COLLECTION CHAMBER	19
<b>CHAPTER 6</b>	
6 ELECTRICAL DIAGRAM OF 73 MLD PLANT	20
<b>CHAPTER 7</b>	
7 POWER CHARGE ANALYSIS	21
<b>CHAPTER 8</b>	
8 KNOW YOUR PLANT STATUS	22
<b>CHAPTER 9</b>	
9 TRANSFORMERS	23
9.1 CALCULATION FOR TRANSFORMER LOSS OF CAPACITY 1600 Kva	25
<b>CHAPTER 10</b>	
10 STUDY OF PUMPS AND MOTORS	26
10.1 OPERATIONAL PERFORMANCE OF PUMP SETS	27



10.1.1	MOTOR AND PUMP PERFORMANCE CHART	27
10.1.2	MOTOR AND PUMP PERFORMANCE CHART	29
10.1.3	MOTOR AND PUMP PERFORMANCE CHART	31
10.2	EFFICIENCY TESTS FOR PUMP SETS	33
<b>CHAPTER 11</b>		
11	QUANTITATIVE ANALYSIS (WATER)	34
11.1	WATER DISTRIBUTION IN MLD (EXISTING)	34
11.2	WATER DISTRIBUTION IN MLD (PROPOSED)	35
<b>CHAPTER 12</b>		
12	LOAD IMPROVEMENTS PROPOSED DUE TO PF & EFFICIENCY CORRECTION	36
<b>CHAPTER 13</b>		
13	ENERGY DISTRIBUTION AMONG VARIOUS COMPONENTS OF PLANT	42
13.1	ENERGY DISTRIBUTION CHART	42
<b>CHAPTER 14</b>		
14	SPECIFIC ENERGY CONSUMPTION	43
<b>CHAPTER 15</b>		
15	BENCHMARKING	44
<b>CHAPTER 16</b>		
16	LIGHT LOAD	45
<b>CHAPTER 17</b>		
17	SENSITIZATION PROGRAM FOR STAFF	46
<b>CHAPTER 18</b>		
18	ENERGY CONSERVATION OPTIONS AND RECOMMENDATIONS	47
<b>CHAPTER 19</b>		
19	CONCLUSION	51
<b>ANNEXURE 1</b>		
	PAYBACK CALCULATIONS	52
A1.1	OPERATIONAL OPTIMISATION OF TRANSFORMERS- ONE KEEP AS STANDBY	52
A1.2	KEEPING AVERAGE WATER LEVEL AS 3.5 AT TWR	53
A1.3	ENERGY EFFICIENCY IN EXISTING PUMPING SYSTEM BY REPLACING INEFFICIENT MOTOR PUMP SET FOR BACKWASH WATER PUMPING	54
A1.4	SUPPLY AND FIXING OF NEW RECYCLING MOTOR PUMP SETS FOR WASH WATER	55
A1.5	ENERGY EFFICIENCY IN EXISTING PUMPING SYSTEM BY REPLACING INEFFICIENT MOTOR ( No.301)	56
A1.6	ENERGY EFFICIENCY IN EXISTING PUMPING SYSTEM BY REPLACING INEFFICIENT MOTOR ( No.201)	57
<b>ANNEXURE 2</b>		
	PRELIMINARY AUDIT NOTE	58

**EXECUTIVE SUMMARY**

Executive Summary						
Consolidated Cost Benefit Analysis of Energy Efficiency Improvement Projects						
KWA WATER TREATMENT PLANT, PANAMKUTTYMALA						
Sl. No.	Projects	Investment in Lakhs Rs.	Cost savings in Rs. per year	Pay back period		Energy saved in Kwh per year
				Year	Month	
1	OPERATIONAL OPTIMISATION OF TRANSFORMERS- ONE KEEP AS STANDBY	0	110814	0	0	19272
2	MAINTAIN 3.8 m WATER LEVEL AT TWR	0	272637	0	0	47415
3	REPLACING LESS EFFICIENT BACK WASH WATER MOTOR PUMPSET BY EFFICIENT ONE HAVING 25HP CAPACITY	380000	545568	0.70	8.4	94881
4	SUPPLY AND FIXING OF NEW RECYCLING MOTOR PUMP SETS FOR WASH WATER @ 30 HP SUBMERSIBLE	600000	1904257	0.32	3.8	331175
5	REPLACING LESS EFFICIENT No.301 TREATED WATER MOTOR PUMPSET BY EFFICIENT ONE @ 300 HP	4800000	2840460	1.69	20.3	493993
6	REPLACING LESS EFFICIENT No.201 TREATED WATER MOTOR PUMPSET BY EFFICIENT ONE @ 300 HP	4800000	1742830	2.75	33.0	303101



## 1. INTRODUCTION

KWA is a PSU under the Govt. of Kerala which is empowered to construct and run the water supply schemes to cater potable water to the public and to construct and run the sewerage schemes in favour of LSGDs. In both cases, the electrical equipment which comes across the different operations in the plant and pumping stations is consuming a tremendous quantity of electricity directly and indirectly. There are 277 HT and more than 2000 LT connections associated with KWA at different pumping stations and WTPs all over Kerala by which more than 3300 MLD water is produced. M/s KWA is liable to pay Rs.3600 million per year to M/s Kerala State Electricity Board Limited. On preliminary study indicates that even the basic principle of energy conservation methodology has not been implemented in our pumping stations owing to a lack of awareness in energy conservation activities. For KWA, the energy audit and water audit are complimentary as both are having the potential to contribute to the existence of KWA. The Govt. of Kerala has formulated the autonomous body to look into the energy audit program in Kerala as the nodal agency, the Energy Management Centre (EMC) is continuously demanding to implement the corrective steps to avoid energy wastages in pumping stations as it is very essential for the financial sustainability of the organization and the prosperity of our nation. It is also realized that the energy audit through the empanelled agencies are more concentrated on energy aspects rather than water wastages as they were less expertise in the latter still it consumes more money and time. The main locations can be identified by audit in both cases viz. the places where less efficiency was reported due to the procedural (operational) errors and the place where losses occurred due to the implementation of outdated technology. It is also taken into consideration that the implementation of advanced technology in this sector will improve the service stability of KWA. The Honourable Managing Director has issued an order to create a team by selecting experienced hands from KWA itself to conduct energy and water audit. The Assistant Engineer in charge of 73 mld WTP at Panamkuttymala had been demanded to conduct the audit at the WTP under her jurisdiction once the order for constituting the audit team by the MD was issued. This is the second assignment of Team, energy audit, Kwa.



## **1.1 VISION**

Promoting good energy management practices in KWA through water and energy audit

## **1.2 MISSION**

Implement energy optimization technologies.

Adopt benchmarking for energy consumption canterers of KWA

## **1.3 SLOGAN**

Measure before leave

## **1.4 SCOPE**

The energy audit is concentrating on two aspects viz.

### 1) Operational optimization

This can be achieved by giving proper training to the staff, implementing a procedural system to fix the responsibility and target the culprits those who are negligent in optimum operation, Transferring technical knowhow to the concerned, which improves the morale also.

### 2) Technology up gradation

There is high scope for implementing advanced technology in KWA since the energy conservations methodologies are vastly developed in the recent era but still, M/s KWA is running with the conventional mechanism.

## **1.5 ENERGY AUDIT TEAM**

The team members of the energy audit constituted as per order number KWA/JB/EW/EMC/EA/7813/2019 dated 17.09.21 by Managing Director KWA

- 1) Sri. Venkiteswaran B, Head Office Vellayambalam
- 2) Sri. Sajan,S , PH Sub Division, Chavara
- 3) Sri. Salmanul Farisi, P H Sub Division, Chavara
- 4) Sri. Jilson Devasia, P H Section, Sulthanbathery
- 5) Sri. Thomson M. C., P H Section, Mananthavady
- 6) Sri. Sajith K., P H Section, Sulthanbathery



Headed by Sri. Thampy.S, Assistant Executive Engineer, Project Division, Alappuzha

Date of Audit: 25.10.2021 to 30.11.2021

### **1.6 ABOUT THE ENERGY AUDIT TEAM, KWA**

This team consists of six operating staff are having more experience in the water and energy sector with academic qualifications @ M Tech, and B Tech. of mechanical and electrical disciplines and they are working under the leadership of a registered Energy Manager.

### **1.7 MAJOR ACTIVITIES OF ENERGY AUDIT TEAM, KWA.**

- 1) Carry out an energy audit in favour of KWA
- 2) Carry out water audit in favour of KWA
- 3) Study and evaluation of energy audit reports submitted by certified energy auditors.
- 4) Inspect the pumping stations for rectification work on energy related issues.
- 5) Technical support to water authority officers on energy related issues.

### **1.8 METHODOLOGY**

- 1) Survey for requirement
- 2) Data collection
- 3) Planning of audit
- 4) Site observation
- 5) Auditing
  - Power measurement
  - Flow measurement
  - Energy balancing
  - Water balancing
- 6) Determination of opportunities for energy reduction and conservation options.
- 7) Exploiting the possibilities to encourage introducing the technology advancement in water and energy related sector at KWA from the R & D institutions.
- 8) Conducting sensitization programs and making consensus for implementing zero investment recommendations.
- 9) Preparation of draft energy audit report including cost benefit analysis.
- 10) Conducting discussions on the draft report with stakeholders.
- 11) Answering queries.





- 12) Preparation of final report.
- 13) Implementing phase by the competent authority.
- 14) Promoting feedback for further corrective actions.



## **2. WTP PANAMKUTTYMALA**

### **2.1 SOURCE**

The source for the Water Supply Scheme is the river Kallada at Tholikode near Punalur in Kollam district. The source is assured due to the K.I.P dam constructed at 22 km upstream of the abstraction point. The 71 MI/d WTP is located at Panamkuttimala, on a hillock at about 1.6 km from the intake works. ( Latitude 9.0024819, and Longitude 76.9188076 )

### **2.2 WORKS CAPACITY**

The 2 MI/d difference between input and output is due to an allowance for water discharged to waste in desludging clarifiers. Filter wash water will be recycled to the head of the works.



### 2.3. RAW WATER QUALITY

Details of the raw water analyses taken during the design phase are presented in the table below:

#### 2.3.1 Results of Raw Water Analysis

Name of the Scheme	Meenad and adjoining Villages						
Source	Kallada River at Proposed intake works						
Sampling Location	15 m from the riverbank collected from the surface						
Date of Sampling							
Parameters	Units	25/10/2021	25/10/2021	25/10/2021	25/10/2021	25/10/2021	25/10/2021
Colour (True)	Pt-Co Scale					<5	<10
Turbidity	(NTU)	2.6	2.4	5.1	1.4	2.7	1.5
pH		7.0	6.8	6.9	6.7	7.0	6.4
Conductivity	( micro Siemens/cm <sup>2</sup> )	38	37	39	37	44	36
Alkalinity	(mg/l as CaCO <sub>3</sub> )	12	16	14	10	14	13
Total hardness	(mg/l as CaCO <sub>3</sub> )	10	10	8	11	11	7
Calcium	(mg/l as	6	4	2	3	2	

REPORT ON ENERGY AUDIT ON 73 MLD WTP AT PANAMKUTTYMALA



hardness	CaCO <sub>3</sub> )						
Chloride	(mg/l as Cl)	13	14	14	12	13	
Sulphate	(mg/l/ as SO <sub>4</sub> )	2	3	4	1	5	
Total Iron	(mg/l as Fe)	1.0	0.8	1.3	1.3	1.0	0.2
Total Manganese	(mg/l as Mn)	0.008	0.006	0.0072	0.0078	0.082	
Ammonia	(mg/l as N)	0.02	0.01	0.02	0.01	0.01	
Nitrate	(µg/l)	25	469	498	722	157	
Phosphate	(µg/l)	7	16	115	110	97	
Permanganate value	(mg/l as O)	0.04	0.12	3.5	0.9	2.8	
UV absorbance	(at 254nm)	0.04	0.04	0.03	0.042	0.046	
Mercury	(mg/l as Hg)	0.00009	ND	ND	ND	ND	
Cadmium	(mg/l as Cd)	ND	ND	ND	ND	ND	

Lead	(mg/l as Pb)	0.029	0.036	0.031	0.034	0.03	
Total Coliform	(No/100ml)	NS	21 & 22	28 & 31	19 & 20	15 & 14	
Faecal Coliform	(No/100ml)	NS	2&2	2 & 2	3 & 3	4 & 4	
Dissolved Oxygen	(mg/l)				6.4	7.0	
<b>Note :</b>							



*1. Dissolved Oxygen values are only indicative*

*2. pH measured in Lab and not at the site, Site value may have been a few decimal points lesser*

*3. NS- No Sample, ND- Not Detected*



### 3. WATER TREATMENT PROCESS

Raw water is treated to remove dissolved natural color, suspended solids, and iron and to produce water free of pathogenic organisms indicated by the absence of coliform bacteria.

Another requirement is the low aluminium concentration that originates from the aluminium sulphate coagulant when coagulation pH is not within an optimum pre-set range.

As a minimum, the treated water quality will comply with the 'desirable limiting' values given in the Indian Drinking Water Quality Standards, the Manual on Water Supply and Treatment, Ministry of Urban Development, Government of India, 1999.

The treatment processes will be designed to produce treated water that is equal to, if not in many respects, better than the desirable limiting values in the Indian Drinking Water Quality Standards. These will be specified as performance criteria for the takeover of the treatment works following completion. Therefore the works should be operated to achieve these performance standards most of the time, with the 'desirable limiting' values in Indian Drinking Water Quality Standards being satisfied all the time.

Table 2 below lists the treated water quality requirements for assessing the performance of the work, and corresponding 'desirable limiting values' in the Indian Drinking Water Quality Standards (IDWQS). The values are given only for those parameters which are affected by the treatment process in place. Values of other parameters except those which occur in particulate form would be equal to those in the raw water. For comparison, guideline values given by World Health Organisation (WHO) (1993), which are the same as those proposed in the 2004 Guidelines are also listed.



**3.1. Treated Water Quality Criteria (Limiting Values)**

Parameter	Performance Standard to be met in 95% of the sample analyzed.	Indian Drinking Water Standard (Desirable Limit) to be met all the time	WHO Guideline Values (1993) and those proposed in 2004 Guideline Values
Colour (° Hazen)	5 °Hazen	5	Should be colourless
Turbidity (NTU)	1.0	1.0	1.0 Not offensive to consumers
Taste and Odour	Unobjectionable	Unobjectionable	0.3
Iron as Fe (mg/l)	0.1	0.3	0.4
Manganese as Mn (mg/l)	0.05	0.1 <sup>#</sup>	0.2
Aluminium as Al (mg/l)	0.1	0.2 <sup>#</sup>	<8.0 (for disinfection)
pH	pHs ±0.4, pHs being the saturation pH value	6.5 to 8.5	Nil
Total coliform (per 100ml)	Nil	Nil	Nil
Faecal coliform (per 100ml)	Nil	0.2*	>0.5**
Free chlorine (after 30 minutes of effective contact time) (mg/l)	>0.5		



# *Iron, manganese, and aluminium values of 0.1 mg/l as Fe, 0.05 mg/l as Mn, and 0.03 mg/l as Al given in IDWQS are too low to comply with. Less stringent values equal to the WHO values will be used.*

\* *The proposed value is low for disinfection. A value of greater than 0.5 mg/l is proposed for 100%ile.*

\*\* *Ct (C – free residual chlorine concentration in mg/l after a contact time t in minutes) > 15 mg.min/l*

The above treated water quality criteria also represent the filter performance except for turbidity, pH, bacteriological quality, and final free chlorine residual. They are influenced by the post filtration treatment. Filtered water turbidity standards will be set at 0.5 NTU (95%ile compliance) and 1 NTU (100%ile compliance).

The performance of clarifiers is defined by the following clarified water quality criteria:

Turbidity:	5 NTU
Colour	5 ° Hazen
Aluminium as Al:	0.5 mg/l

A conventional treatment process using coagulation, flocculation, clarification, rapid sand filtration, and disinfection will be used.

Detailed below are brief descriptions of the adopted treatment process.

- Coagulation by dosing aluminium sulphate,
- Flocculation under moderate intensity mixing conditions,
- Clarification of flocculated water with sludge blanket / Lamella clarifiers,
- Filtration of clarified water by rapid gravity sand filters,
- Disinfection of filtered water by chlorine dosing,
- Final pH-correction by dosing lime,
- Clarifier sludge thickening and settlement in sludge lagoons.

The plant items for the treatment process are briefly described below.





### **3.2. INLET WORKS**

The inlet works will comprise an inlet pipe equipped with a magnetic flow meter feeding a cascade aerator with stilling basing. Hydrated lime will be dosed at the aerator inlet. The outlet from the aerator will connect to a channel.

### **3.3. MIXING FLUME**

The channel from the aerator will be provided with a flume where chlorine and hydrated aluminium sulphate flocculants will be dosed. Mixing will be by hydraulic means.

There is a flow division chamber to divide the flow emerging from the flume equally between the clarifiers.

### **3.4. CLARIFLOCCULATION**

Clarifiers are the lamella sedimentation type with mechanical flocculates.

The Lamella clarifiers have a settling rate of  $0.85 \text{ m}^3/\text{h}/\text{m}^2$  of the projected plate area.

In sludge blanket clarifiers, sludge is collected in a series of hoppers placed at the top level of the blanket. The hoppers of each clarifier have separate manifolds.

Lamella sedimentation tanks are provided with sludge scrapers.

Desludging of clarifiers is under the hydrostatic head; the desludging valves are fitted with pneumatic actuators to allow for automatic desludging on timer control

.

### **3.5. RAPID GRAVITY FILTERS**

After clarification, the clarified water will flow to the rapid gravity sand filters for the removal of residual suspended solids. The filtration unit will consist of six individual filters, which can be operated independently via motorized valves fitted with electric or pneumatic actuators.



### 3.6. WASH WATER REUSE

Used wash water from the filters is collected in a tank and pumped to the works inlet chamber, the rate will be less than 5% of maximum works inflow. The tank is provided with two compartments to allow one to be taken out for cleaning.

Two pumps (1 duty, 1 standby) of the Submersible type are provided. **The used wash water flow to the works inlet is not carried out since the motor is under repair.**

## 4. CONTROL AND MONITORING SYSTEMS


The treatment works are provided with modern facilities to operate the treatment plant items. A central computer based Supervisory Control and Data Acquisition (SCADA) system will be provided at the water treatment works to monitor alarms, plant status, and analogue signals.

The SCADA system is situated in a dedicated control room in the works administrative building (filter building). The SCADA system receives the data from the works monitoring and control systems, and the raw water pumping station. The raw water pumps are operable from the works control room. Data from the works is relayed to the Regional Control Centre, located at the scheme administrative building.



## 5. WATER FLOW DIAGRAMS AND PHOTOS

### 5.1 WATER FLOW DIAGRAM



Water flow diagram for 73 mld meenad scheme



## 5.2. AERATOR



## 5.3. LAMELLAE CLARIFIER






#### 5.4. CLEAR WATER PUMP HOUSE






### 5.5 Preliminary treated water pumping plant drawing (A)




### 5.6 Preliminary treated water pumping plant drawing (B)





**5.7. Treated water system flow/head curves**






## 5.8. BACKWASH WATER COLLECTION CHAMBER







**6. ELECTRICAL DIAGRAM OF 73 MLD PLANT**



Electrical diagram of 73 mld plant –Meenad Punalur



**7. POWER CHARGE ANALYSIS**

<b>Electricity Bill Details (2020-2021)</b>																		
	Name of the Consumer			KERALA WATER AUTHORITY, KWA, HWS Panamkuttymala														
	CONTRACT LOAD			774 KVA			75%=581			CLEAR WATER PUMPING								
	Tariff			HT I (A) INDUSTRIAL			Consumer number			LCN 17/549 4			KSEB Section			KARAVLOOR		
Month	KWh @ Rs.5.75				KVA @ Rs.340													
	Z1	Z2	Z3	Total	Z1	Z2	Z3	Max	PF	PF penalty/incentive in Rs.	Total Energy charges in Rs.	Rs/KWh	Monthly production in ML	KWh/MLD	Rs/MLD			
Sep-20	154800	51960	78660	285420	494	531	485	531	0.98	-24617	1849765	6.48	1613.66	176.88	1146.32			
Oct-20	161060	55180	75740	291980	497	501	483	501	0.98	-25183	1887739	6.47	1569.03	186.09	1203.12			
Nov-20	133120	49120	74480	256720	492	514	500	514	0.98	-22142	1683628	6.56	1552.37	165.37	1084.55			
Dec-20	164040	53980	74960	292980	507	506	512	512	0.98	-25270	1893528	6.46	1615.51	181.35	1172.09			
Jan-21	157480	52180	80420	290080	507	527	505	527	0.98	-25019	1876740	6.47	1556.1	186.41	1206.05			
Feb-21	142940	47440	94480	284860	508	517	501	517	0.98	-24569	1846523	6.48	1520.71	187.32	1214.25			
Mar-21	157420	53400	106080	316900	509	505	527	527	0.97	-18222	2041106	6.44	1731.76	182.99	1178.63			
Apr-21	157100	51080	105840	314020	527	511	530	530	0.97	-18056	2024351	6.45	1579.2	198.85	1281.88			
May-21	137780	49300	72920	260000	599	544	551	599	0.97	-14950	1716210	6.60	1508.48	172.36	1137.71			
Jun-21	146100	51020	76400	273520	509	507	499	509	0.99	-31454	1773015	6.48	1453.25	188.21	1220.03			
Jul-21	158860	55940	82160	296960	506	525	514	525	0.99	-34150	1908030	6.43	1525.43	194.67	1250.81			
Aug-21	150860	51320	78540	280720	517	517	507	517	0.98	-24212	1822558	6.49	1561.33	179.80	1167.31			



## 8. KNOW YOUR PLANT STATUS

<b>PRODUCTION COST (KNOW YOUR PLANT)</b>							
<b>Production cost</b>							
<b>Yearly production in mld</b>					<b>19048</b>		
<b>Sl. No.</b>	<b>Components</b>	<b>Unit</b>	<b>Quantity</b>	<b>Rate in Rs.</b>	<b>Amount in Rs.</b>	<b>Cost in Rs.per mld</b>	<b>Cost in Rs.per kl</b>
	Electrical expenses for raw water pumping (LCN: 17/5433)	<b>Kwh</b>			<b>66765629</b>	<b>3505.13</b>	
1	Electrical expenses for clear water pumping and allied (LCN: 17/5494)	Kwh	3444160	6.48	22318157	1171.68	
2	Salaries				8998566	472.4153	
3	Wages				528296	27.73499	
4	O and M expenditure				9036648.9	474.4146	
	<b>Chemicals</b>					0	
5	Alum	MT	225.495	22243	5015685.29	263.3182	
6	Lime	MT	37.25	12980	483505	25.3835	
7	Chlorine	MT	36	12390	446040	23.41663	
<b>Total</b>					46826897.9	5963.488	<b>5.963488</b>

## 9. TRANSFORMERS





TRANSFORMER		
1	MAKE	INDOTECH TRANSFORMERS
2	RATED KVA	1600
3	RATED VOLTAGE	HV 11000 LV 433
4	AMPERE	HV 83.98 LV 2133.39
5	PHASE	3
6	SR NO	IT- 43449
7	WORK ORDER NO	IT-3054
8	CUSTOMER'S REF	MGB PO 749 DATED 28.4.2009
9	CUSTOMER	M/S VA TECH WABAG
10	YEAR OF MANUFACTURE	2009
11	TYPE OF COOLING	ONAN
12	FREQUENCY	50 HZ
13	IMPEDENCE %	6.36
14	VECTOR GROUP REF NO	DYN11
15	CORE & WINDING Kg	2135
16	OIL Kg	1385
17	TOTAL WEIGHT Kg	5335
18	OIL IN LITERS	1630



<b>9.1 Calculation for transformer loss of capacity 1600 Kva</b>							
No load loss in watts =2200			Full load loss in		Total load in kVA=694		
Total loss= no load loss +(% of load/100) <sup>2</sup> * full load loss							
Sl. No.	Status		Percentage load of	No load loss in Watts	Load loss in Watts	Sub total	Total loss in Watts
1	Transformer 1 alone in operation		43.4	2200	3951		6151
2	Transformer 2 alone in Operation		43.4	2200	3951		6151
3	Transformer 1 & 2 are Equally Shared	Transfer mer 1	21.7	2200	989	3189	
		Transfer mer 2	21.7	2200	989	3189	6378
4	Load is connected anyone and the other one is in on position (existing)	Transfer mer 1	43.4	2200	3951	6151	
		Transfer mer 2	0	2200	0	2200	8351



## 10. STUDY OF PUMPS AND MOTORS





**10.1. OPERATIONAL PERFORMANCE OF PUMP SETS**

<b>10.1.1. Motor and Pump performance chart</b>					
<b>Utility</b>	<b>Description</b>	<b>Parameters</b>		<b>Design/Name plate details</b>	<b>Operating details</b>
<b>General</b>	Location	MEENAD Jica plant			
	Application	Clear water pumping	No.201		
	Location ID	73MLD -WTP			
<b>Pipeline</b>	Material			MS	
	Size		mm	1000	
	Length		M	500	
<b>Motor</b>	Make	Marathon Electric			
	Year of Manufacture	2000			
	Type	CF			
	ID. No.	275622520003			
	Principle of operation	Squirrel cage induction			
	Power		HP	300	
	Speed		RPM	1488	
	Frequency		Hz	50	
	Voltage		Volt	415	401
	Current		Amps	368	326
	PF				0.97
	Starting mechanism	Soft starter			
	Input		Kw		220
% of loading of on pump		%		100	
<b>Pumps</b>	<b>Make</b>	<b>Kirlosker Brothers</b>			
	<b>Year of Manufacture</b>	2008			
	<b>Type</b>	CF-HS			
	<b>ID. No.</b>	1733008008			
	<b>Speed</b>		RPM	1488	





	Description	Parameters		Design/Name plate details	Operating details
	Head		M	38.7	39
	Density		Kg/M3	1000	
	Gravitational Constant		M/s2	9.81	
	Prime mover rating		HP	300	
	Type of control	Throttling			
	Status of valve	Open fully			
	Working Hours		Hrs		16
	% of loading on head		%		100.77519
	% of loading on discharge		%		89.238753
	Output		kW		140
<b>Combined</b>	<b>Efficiency</b>		%		63.636364



**10.1.2. Motor and Pump performance chart**

Utility	Description	Parameters		Design/Name plate details	Operating details
<b>General</b>	Location	MEENAD Jica plant			
	Application	clearwater pumping	No. 301		
	Location ID	73MLD -WTP			
<b>Pipeline</b>	Material			MS	
	Size		mm	1000	
	Length		M	500	
<b>Motor</b>	Make	Marathon Electric			
	Year of Manufacture	2000			
	Type	CF			
	ID. No.	2.75623E+11			
	Principle of operation	Squirrel cage induction			
	Power		HP	300	
	Speed		RPM	1488	
	Frequency		Hz	50	
	Voltage		Volt	415	401
	Current		Amps	368	340
	PF				0.97
	Starting mechanism	Soft starter			
	Input	Kw			229
	% of loading on pump	%			104.0909091
<b>Pumps</b>	Make	Kirlosker Brothers			
	Year of Manufacture	2008			
	Type	CF-HS			



	Description	Parameters		Design/Name plate details	Operating details
	Speed		RPM	1488	
	Flow/Discharge		M3/Hr	1479.178	1265
	Head		M	38.7	39
	Density		Kg/M3	1000	
	Gravitational Constant		M/s2	9.81	
	Prime mover rating		HP	300	
	Type of control	Throttling			
	Status of valve	Open fully			
	Working Hours		Hrs		24
	% of loading on head		%		100.7751938
	% of loading on discharge		%		85.52047151
	Output		Kw		134
<b>Combined</b>	Efficiency				58.51528384



**10.1.3. Motor and Pump performance chart**

Utility	Description	Parameters		Design/Name plate details	Operating details
<b>General</b>	Location	MEENAD Jica plant			
	Application	Clear water pumping for backwashing			
	Location ID	73MLD -WTP			
<b>Pipeline</b>	Material			MS	
	Size		mm	150	
	Length		M	25	
<b>Motor</b>	Make	SEIMENS			
	Year of Manufacture	2000			
	Type	CF			
	ID. No.	64136042			
	Principle of operation	Induction			
	Power		HP	25	
	Speed		RPM	1463	
	Frequency		Hz	50	
	Voltage		Volt	415	413
	Current		Amps	34	23
	PF				0.97
	Starting mechanism	Soft starter			
Input					
			Kw		16



	Description	Parameters		Design/Name plate details	Operating details
<b>Pumps</b>	<b>Make</b>	<b>Kirlosker</b>			
	<b>Year of Manufacture</b>				
	<b>Type</b>	<b>CF-HS</b>			
	<b>ID. No.</b>	<b>1745608057</b>			
	<b>Speed</b>		RPM	1450	
	<b>Flow/Discharge</b>		M3/Hr	165	107
	<b>Head</b>		M	22	17
	<b>Density</b>		Kg/M3	1000	
	<b>Gravitational Constant</b>		M/s <sup>2</sup>	9.81	
	<b>Prime mover rating</b>		HP	25	
	<b>Type of control</b>	<b>Throttling</b>			
	<b>Status of valve</b>	<b>Open fully</b>			
	<b>Working Hours</b>		Hrs		9
	<b>% of loading on head</b>		%		77.27272727
	<b>% of loading on discharge</b>				64.84848485
	<b>Output</b>		Kw		4.9564044
<b>Combined</b>	Efficiency		%		30.9775275


**10.2. EFFICIENCY TESTS FOR PUMP SETS**

<b>EFFICIENCY TESTS FOR PUMP SETS</b>										
		<b>25-10-2021</b>	<b>No. of trial</b>	<b>3</b>	<b>Time</b>	<b>11:00:00 to 1.30 pm</b>				
<b>Location</b>	<b>No.</b>	<b>Capacity in HP</b>	<b>INPUT DATAS</b>			<b>OUTPUT DATAS</b>			<b>Efficiency in %</b>	
			<b>Voltage in Volts</b>	<b>Current in Amps</b>	<b>PF</b>	<b>INPUT in KW</b>	<b>Discharge in M<sup>3</sup>/S</b>	<b>Head in m</b>	<b>OUTPUT in KW</b>	
TWPH	201	300	401	326	0.97	219.62	0.367	39	140.41	63.93
TWPH	301	300	401	340	0.97	229.06	0.3514	39	134.44	58.69
BWPH	201	25	413	23	0.97	15.96	0.02972	17	4.96	31.06



## 11. QUANTITATIVE ANALYSIS (WATER)


11.1. Water distribution in mld (Existing) One year average			
Raw water	Backwash water	Clear water	Recycled water
54.473	2.568	52.18563889	0





**11.2. WATER DISTRIBUTION IN MLD (PROPOSED)**

Water distribution in mld (Proposed)				
Raw water	Backwash water	Clear water	Recycled water	Consumed backwash water
52.473	2.568	52.18563889	2	0.568



- Clear water
- Recycled water
- Consumed backwash water





**12. LOAD IMPROVEMENTS PROPOSED DUE TO PF & EFFICIENCY CORRECTION**

LOAD IMPROVEMENTS PROPOSED DUE TO PF & EFFICIENCY CORRECTION											
SL. No.	MAKE	VO LT	A MP S	H P	K W	dby	P. F	Motor name	AREA	PROPOSED LOAD	Percentage of load sharing
1	SIEMENS	415 Δ	4.4	3	2.2	SERVICE	0.85	Flocculator		1.93	0.33
2	SIEMENS	415 Δ	4.4	3	2.2	SERVICE	0.85	Flocculator		1.93	0.33
3	SIEMENS	415 Δ	4.4	3	2.2	SERVICE	0.85	Flocculator		1.93	0.33
4	SIEMENS	415 Δ	4.4	3	2.2	SERVICE	0.85	Flocculator		1.93	0.33
5	SIEMENS	415 Δ	4.4	3	2.2	SERVICE	0.85	Flocculator		1.93	0.33
6	SIEMENS	415 Δ	4.4	3	2.2	SERVICE	0.85	Flocculator		1.93	0.33
7	SIEMENS	415 Δ	4.4	3	2.2	SERVICE	0.85	Flocculator		1.93	0.33
8	SIEMENS	415 Δ	4.4	3	2.2	SERVICE	0.85	Flocculator	FLOCCULATOR	1.93	0.33
9	SIEMENS	415 Δ	4.4	3	2.2	SERVICE	0.85	Flocculator	MOTOR	1.93	0.33
10	SIEMENS	415 Δ	4.4	3	2.2	SERVICE	0.85	Flocculator		1.93	0.33
11	SIEMENS	415 Δ	4.4	3	2.2	SERVICE	0.85	Flocculator		1.93	0.33



12	SIEMENS	415 Δ	4.4	3	2.	SERVICES	0.	Flocculator		1.93	0.33
13	SIEMENS	415 Δ	4.4	3	2.	SERVICES	0.	Flocculator		1.93	0.33
14	SIEMENS	415 Δ	4.4	3	2.	SERVICES	0.	Flocculator		1.93	0.33
15	SIEMENS	415 Δ	4.4	3	2.	SERVICES	0.	Flocculator		1.93	0.33
16	SIEMENS	415 Δ	4.4	3	2.	SERVICES	0.	Flocculator		1.93	0.33
17	CROMPTON GREENAVES	415	2.0 star	1	0.	SERVICES	0.	Clarifier		0.63	0.11
18	CROMPTON GREENAVES	415	2.0 star	1	0.	SERVICES	0.	Clarifier		0.63	0.11
19	CROMPTON GREENAVES	415	2.0 star	1	0.	SERVICES	0.	Clarifier	CLARIFIER MOTOR	0.63	0.11
20	CROMPTON GREENAVES	415	2.0 star	1	0.	SERVICES	0.	Clarifier		0.63	0.11
21	SIEMENS	415 Δ	7		3.	SERVICES	0.	Air compressor	FILTER HOUSE	3.28	0.56
22	SIEMENS	415 Δ	7		3.	S/B	0.	Air compressor	COMPRESSOR MOTOR		0.00
23	SIEMENS	415	96	7	55	SERVICES	0.	Air		48.20	8.26



	NS			4		CE	85	blower			
24	SIEME NS	415	96	7 4	55	SERVI CE	0. 85	Air blower	FILTER HOUSE BLOWER	48.20	8.26
25	SIEME NS	415	96	7 4	55	S/B	0. 85	Air blower	MOTOR		0.00
26	SIEME NS	415 Δ	34	2 5	18 .5	SERVI CE	0. 83	Works water		14.97	2.57
27	SIEME NS	415 Δ	34	2 5	18 .5	S/B	0. 83	Works water	WASH WATER MOTOR		0.00
28	CROM PTON GREA VES	415	2.0 star	1	0. 75	SERVI CE	0. 81	SLUDG E THICK NER		0.63	0.11
29	CROM PTON GREA VES	415	2.0 star	1	0. 75	SERVI CE	0. 81	SLUDG E THICK NER	SLUDGE THICKN NER	0.63	0.11
30	SIEME NS	415	4.5	3	2. 2	SERVI CE	0. 85	Sludge feed pump		1.93	0.33
31	SIEME NS	415	4.5	3	2. 2	SERVI CE	0. 85	Sludge feed pump		1.93	0.33
32	SIEME NS	415	4.5	3	2. 2	SERVI CE	0. 85	Sludge feed pump	SLUDGE FEED MOTOR	1.93	0.33
33	SIEME NS	415	4.5	3	2. 2	SERVI CE	0. 85	Sludge feed pump		1.93	0.33
34	MARA THON	415	368	3 0	22 0	SERVI CE	0. 87	Treated water		186.65	32.00



				0				pump			
35	MARATHON	415	368	3 0 0	22 0 0	SERVI CE	0. 87	Treated water pump		186.65	32.00
36	MARATHON	415	368	3 0 0	22 0 0	S/B	0. 87	Treated water pump	TREATED WATER		0.00
37	MARATHON	415	368	3 0 0	22 0 0	S/B	0. 87	Treated water pump	PUMP		0.00
38	KIRSO LKAR BROTHERS LTD	415	4.2	3	2. 2	SERVI CE	0. 87	Chlorine pre booster pump		1.97	0.34
39	KIRSO LKAR BROTHERS LTD	415	4.2	3	2. 2	SERVI CE	0. 87	Chlorine post booster pump	CHLORINE PLANT	1.97	0.34
40	KIRSO LKAR BROTHERS LTD	415	4.2	3	2. 2	S/B	0. 87	Chlorine post booster pump			0.00
41	SIEMENS	415	7	5	3. 7	SERVI CE	0. 86	Alume feed pump		3.28	0.56
42	SIEMENS	415	7	5	3. 7	S/B	0. 86	Alume feed pump	ALUM PLANT		0.00

REPORT ON ENERGY AUDIT ON 73 MLD WTP AT PANAMKUTTYMALA



43	SIEMENS	415	3.5	2	1.5	SERVICE	0.81	Alume recirculation pump		1.25	0.21
44	SIEMENS	415	3.5	2	1.5	S/B	0.81	Alume recirculation pump			0.00
45	SIEMENS	415	4.4	3	2.2	SERVICE	0.85	Lime feed pump	LIME PLANT	1.93	0.33
46	SIEMENS	415	4.4	3	2.2	S/B	0.85	Lime feed pump			0.00
41	SIEMENS	415	4.4	3	2.2	SERVICE	0.86	Alume Agitator		1.95	0.33
42	SIEMENS	415	7	5	3.7	SERVICE	0.86	Alume Agitator		3.28	0.56
43	SIEMENS	415	3.5	2	1.1	SERVICE	0.81	Lime agitator	ALUM PLANT	0.92	0.16
44	SIEMENS	415	3.5	2	1.1	SERVICE	0.81	Lime agitator		0.92	0.16
45	KIRLOSKER	415	40.0	30	22.0	NOT IN SERVICE	0.87	Recycling	<b>RECYCLING TANK</b>	18.67	3.20
46	KIRLOSKER	415	40.0	30	22.0	NOT IN SERVICE	0.87	Recycling			0.00
	LIGHT LOAD				16.8					16.82	2.88
	TOTAL				12						0.00

REPORT ON ENERGY AUDIT ON 73 MLD WTP AT PANAMKUTTYMALA




	KW				28					
	TOTAL				69					<b>583.23</b>
	KW IN				8					100.0
	SERVI									0
	CE									



**13. ENERGY DISTRIBUTION AMONG VARIOUS COMPONENTS OF PLANT**

Energy distribution among the various components of plant																	
	Flocculator	Clarrifier	Air compressor	Air blower	Work - wash water	SLUDGE THICKNER	Sludge feed pump	Treated water pump	Chlorine post boster pump	Alume feed pump	Alume recirculation pump	Lime feed pump	Alume Agitator	Lime agitator	Re cycling	Light load	Total
Rated power requirement in Kw	30.85	2.51	3.28	96.39	14.97	1.25	7.71	373.31	3.95	3.28	1.25	1.93	5.23	1.84	18.67	16.82	
Operating time( in hours) per day	24	24	18	0.3	10	0	16	24	24	24	24	24	24	24	6	24	
Energy consumption in kWh per day	740.29	60.12	59.05	28.92	149.74	0.00	123.38	8959.38	94.71	78.73	30.06	46.27	125.54	44.09	111.99	403.66	11055.93

**13.1 ENERGY DISTRIBUTION CHART**





#### **14. SPECIFIC ENERGY CONSUMPTION**

The existing specific energy consumption is 183.36 kWh per mld of water for the entire process of filtration of daily production of 52.19 mld against the rated discharge of 71 mld. The specific energy consumption can be reduced to 150 kWh per mld of water filtration once the recommendation is executed.



**15. BENCHMARKING**

BENCHMARKING		
Existing design load in Kw	Average load in kW	Design load proposed in kW
698	539	583
Note; It is ascertained that the existing average load is comparatively less due to the operation of the plant in a lesser capacity		

**16. LIGHT LOAD**

<b>LIGHT LOAD</b>					
SL NO		WATT	UNIT	QUANTITY	TOTAL (Watts)
	<b>LIGHT LOAD IN CLARIFIER AND GALLERY</b>				
1	MERCURY LAMP	70	Nos	25	1750
	<b>CHLORINE SHED</b>				0
1	MERCURY LAMP	70	Nos	5	350
	<b>USED WASH WATER TANK</b>				0
1	MERCURY LAMP	70	Nos	3	210
2		15	Nos	3	45
	<b>FILTER BED AND GALLERY</b>				0
1	MERCURY LAMP	70	Nos	59	4130
2	TUBE LIGHT	40	Nos	3	120
3	STREET LIGHT	200	Nos	6	1200
	<b>BLOWER ROOM</b>				0
1	FLUORESCENT TUBE	40	Nos	7	280
	<b>LAB AND OFFICE ROOM</b>				0
1	FLOURESENT TUBE	40	Nos	38	1520
2	FLOURESENT TUBE	60	Nos	3	180
					0
1	A/C 2 TON	<b>3516.85</b>	Nos	<b>2</b>	7033.7
	<b>Total</b>				<b>16818.7</b>



## 17. SENSITIZATION PROGRAM FOR STAFF



There was no wide level of acceptance for energy audit as it was mistakenly interpreted as energy audit is a fault-finding mechanism similar to other audits. The success of any audit is depended on the transparency and the involvement of the stakeholders. The cooperation and coordination among the staff are very essential for the collection of data as well as for the successful implementation of the audit report. During the awareness camp the Assistant Engineer Smt. Haisal Harison and operating staff were present. The discussions were fruitful and the confidence among the staff was improved. The preliminary recommendations were also discussed and ensured cooperation for implementing the same.



## **18. ENERGY CONSERVATION OPTIONS AND RECOMMENDATIONS**

### **18.1) OPERATIONAL OPTIMISATION OF TRANSFORMERS- ONE KEEP AS STANDBY**

There are two numbers Transformers @1600 KVA each to step down the transmission voltage. On verification, it is understood that both transformers are in the ON position. On comparison of different options of operations with the no-load and load losses, it is realized that it could be better to operate as one must be kept as stand by. The savings in respect of finance and energy is postulated in the calculation sheet of the executive summary. This is the zero investment recommendation. It is also proposed to change over the utilization of each transformer once in two months to ensure both are operating frequently.

### **18.2) INCREASING OF AVERAGE WATER LEVEL TO 0.5 M IN THE TWR**

It is observed that the average water level maintained in the Treated water reservoir is below 3 m against the maximum level of 4.3 m. On experiment, it is realized that it could be easy to increase the average water level to 3.5 m to reduce the pumping charge. The savings in respect of finance and energy is postulated in the calculation sheet of the executive summary. This is the zero investment recommendation

### **18.3) REPLACING LESS EFFICIENT BACKWASH WATER MOTOR PUMP SET BY EFFICIENT ONE HAVING 25HP CAPACITY.**

On efficiency test of backwash water pump sets, it realized that this mechanism is performing with very low efficiency i.e. 31%. It is recommended to replace the same with a more efficient one. The savings in respect of finance and energy is postulated in the calculation sheet of the executive summary.

### **18.4) SUPPLY AND FIXING OF NEW RECYCLING MOTOR PUMP SETS FOR WASH WATER @ 30 HP SUBMERSIBLE.**



The existing mechanism to recycle the wash water @ 2 mld is not working as the motor pump sets are under repair. The water available @ 2 mld at 120 m head is draining out without recycling even the structure for the same is already available. This proposal is to utilize this water to reduce the pumping cost at raw water pumping stations however less quantity energy has to consume additionally at the clear water pumping station. The detailed payback calculation is accompanied by executive summary.

#### 18.5) REPLACING LESS EFFICIENT No.301 TREATED WATER MOTOR PUMPSET BY EFFICIENT ONE @ 300 HP.

The motor pump sets for clear water pumping is the main energy drawing machinery in the wtp. On the efficiency test, it is observed that the efficiency is only 59 % for this pump set. It is recommended to replace the same with most efficient one. The savings in respect of finance and energy is postulated in the calculation sheet of the executive summary.

#### 18.6) REPLACING LESS EFFICIENT No.201 TREATED WATER MOTOR PUMPSET BY EFFICIENT ONE @ 300 HP

The motor pump sets for clear water pumping is the main energy drawing machinery in the wtp. On the efficiency test, it is observed that the efficiency is only 64 % for this pump set. It is recommended to replace the same with most efficient one. The savings in respect of finance and energy is postulated in the calculation sheet of the executive summary.

#### 18.7) GENERAL RECOMMENDATION FOR THE OPERATION MOTORS

Inadequate maintenance of motors can significantly increase losses and lead to unreliable operation. For example, improper lubrication can cause increased friction in both the motor and associated drive transmission equipment. Resistance losses in the motor, which rise with the temperature, would increase. Providing adequate ventilation and keeping motor cooling ducts clean can help dissipate heat to reduce excessive losses. The life of the insulation in the motor would also be longer: for every 10o C increase in motor operating temperature over the recommended peak, the time before rewinding would be needed is estimated to be halved.



A checklist of good maintenance practices to help ensure proper motor operation would include:

1. Inspect motors regularly for wear in bearings and housings (to reduce frictional losses) and for dirt/dust in motor ventilating ducts (to ensure proper heat dissipation).
2. Checking load conditions to ensure that the motor is not over or under-loaded. A change in motor load from the last test indicates a change in the driven load, the cause of which should be understood.
3. Lubricating appropriately. Manufacturers generally give recommendations for how and when to lubricate their motors. Inadequate lubrication can cause problems, as noted above. Over lubrication can also create problems, e.g. excess oil or grease from the motor bearings can enter the motor and saturate the motor insulation, causing premature failure or creating a fire risk.
4. Checking periodically for proper alignment of motor and the driven equipment. This is the zero investment recommendation. Improper alignment can cause shafts and bearings to wear quickly, resulting in damage to both the motor and the drive equipment.
5. Ensuring that supply wiring and terminal box are properly sized and installed. Inspect regularly the connections at the motor and starter to be sure that they are clean and tight.
6. Valve operation has to be ensured on starting and stopping of the motor to ensure the low load on starting and to protect the motor from backpressure respectively.
7. The logbook has to be maintained in such a way that the voltage and current of every hour are documented so that to avail the same for future references.



### **18.8) SUBSTITUTION BY SOLAR POWER**

The possibility for renewable energy (solar) to meet the demand for light load @ 20 KVA can also be explored, depending on the availability of the required intensity of sun rays throughout the day/year.



## 19. CONCLUSION

The objective of the study was to delineate the issues in energy consumption of wtp, to optimize the method of operation, to understand the extent of deviation from the standard of operation, and to explore the possibility of adopting advanced technologies in our sector. On evaluation, it may be realized that each power utility center has a unique optimization need. It is also realized that the present specific energy consumption of wtp is 183.36 kWh per MLD. The kWh per MLD consumption is comparatively low in the filter house as the head creation required is less. Benchmarking for energy use has been proposed and it can be achieved by introducing the proposed operating procedure.

This plant is constructed on proper planning and operating with proper procedure, still, we have energy saving options to be implemented which are listed for implementation.

In addition, the effect of the implementation of zero investment recommendations can be viewed by comparing the energy bills of the pre-and post- audit months.





**ANNEXURE 1**

**A.1.1 PAYBACK CALCULATIONS**

<b>OPERATIONAL OPTIMISATION OF TRANSFORMERS- ONE KEEP AS STANDBY</b>					
		<b>No load loss in Watts</b>	<b>Load loss in Watts</b>	<b>Total Loss in Watts</b>	
<b>Load status</b>	<b>Load is connected to anyone and the other one is in On position (existing)</b>	<b>4400</b>	<b>3951</b>	<b>8351</b>	
	<b>Transformer No.1 or No.2 alone in operation latter in the off position</b>	<b>2200</b>	<b>3951</b>	<b>6151</b>	
Savings in kW					2.2
No. working Hours per year					8760
Energy savings per year in kWh					19272
Cost in Rs. per kWh					5.75
Amount Savings in Lakhs per year					1.10814



**A1.2**

<b>Keeping average water level as 3.5 at TWR</b>				
	<b>Description</b>	<b>Unit</b>	<b>Old System</b>	<b>New System</b>
	<b>Average Suction level of Treated water Reservoir</b>	<b>m</b>	<b>3</b>	<b>3.5</b>
Requirement	Head	m	38.7	38.2
	Flow	m <sup>3</sup> /s	0.822	0.822
	Density of water	kg/m <sup>3</sup>	1000	1000
	Gravitational Constant	m/s <sup>2</sup>	9.81	9.81
	Hydraulic Power is required to meet the demand by existing pump set	kW	312.07	308.04
	Total Electrical Power drawn to meet the requirement	kW	418.94	413.53
	Unit Cost for power	Rs./kWh	5.75	5.75
	Annual operating Hours	Hours	8760	8760
	Annual energy consumption	kWh /year	3669931	3622516
	Annual power Savings, kWh	kWh		47415.1
	Annual Savings	Rs. In Lakhs		2.72637
	Investment required in Lakhs	Rs, in lakhs		0
	Simple Payback period	In years		0
		In months		0


**A1.3**

<b>Energy Efficiency in Existing Pumping system by replacing inefficient motor Pump set for backwash water pumping</b>				
	<b>Description Unit</b>	<b>Unit</b>	<b>Old System</b>	<b>New System</b>
	Type of Motor	Induction		
	Class of Motor		Standard	IE2
	Motor power (rated)	Kw	18.5	18.50
	Efficiency (rated)	%	95.5	95.50
	Combined system efficiency of the system (measured)	%	31.06	
	Pump efficiency	%		78.00
	The combined efficiency of the system (rated)	%	70	74.49
<b>Requirement</b>	Head	m	22	22.00
	Flow	m <sup>3</sup> /s	0.045833	0.05
	Density of water	kg/m <sup>3</sup>	1000	1000.00
	Gravitational Constant	m/s <sup>2</sup>	9.81	9.81
	Hydraulic Power, required to meet the demand by existing pump set	kW	9.89	9.89
	Total Electrical Power drawn to meet the requirement	kW	31.85	13.28
	Unit Cost for power	Rs./kWh	5.75	5.75
	Annual operating Hours @14 hrs per day	Hours	5110	5110.00
	Annual energy consumption	kWh /year	162738.168	67856.73
	Annual power Savings, kWh	kWh		94881.44
	Annual Savings	Rs. In Lakhs		5.46
	Proposed load	Kw		18.50
	Investment required in Lakhs	Rs, in		3.80



	@15225 / hp	lakhs	
	Simple Payback period	In years	0.70
		In months	8.36

**A1.4**

**SUPPLY AND FIXING OF NEW RECYCLING MOTOR PUMP SETS FOR WASH WATER**

Description Unit	Unit	Recurring Savings
Head for Raw water pumps	m	130
Quantity of water required to pump for recycling	mld	2
Required additional head due to the recycling	m	10
Head savings	m	120
Flow	m <sup>3</sup> /s	0.0231
Density of water	kg/m <sup>3</sup>	1000
Gravitational Constant	m/s <sup>2</sup>	9.81
Hydraulic power	kW	29.52
Electrical power would have been incurred with 70% of the system	kW	42.17
Energy charge in Rs./kWh		5.75
Working hours/year		8760
kWh can be saved	kWh	369430
Energy charge would have been incurred (This will reflect in the power bill of Raw water pumping station)	Rs.	2124221
The density of recycled water	kg/m <sup>3</sup>	1250
Flow	m <sup>3</sup> /s	0.0231
Additional kWh required to operate recycling pump sets of 30 HP having 65% efficiency	kWh	38255
The additional amount required to operate recycling pump sets per year (This will reflect in the power charge of WTP)	Rs.	219964
Investment required in Lakhs	Rs.	6.00



Net Savings in kWh per year	kWh	331175
Savings in Rs.per year	Rs	1904257
Simple Payback period	In years	0.32
	In months	3.78

**A1.5**

<b>Energy Efficiency in Existing Pumping system by replacing inefficient motor ( No. 301)</b>				
	<b>Description Unit</b>	<b>U nit</b>	<b>Old System</b>	<b>New System</b>
	Type of Motor	Induction		
	Class of Motor		Standard	IE2
	Motor power (rated)	Kw	220	210.00
	Efficiency (rated)	%	95.5	95.50
	Combined system efficiency of the system (measured)	%	58.69	
	Pump efficiency	%		78.00
	The combined efficiency of the system (rated)	%	70	74.49
<b>Requirement</b>	Head	m	38.7	38.70
	Flow	m <sup>3</sup> /s	0.411	0.41
	Density of water	kg/m <sup>3</sup>	1000	1000.00
	Gravitational Constant	m/s <sup>2</sup>	9.81	9.81
	Hydraulic Power, required to meet the demand by existing pump set	kW	156.03	156.03
	Total Electrical Power drawn to meet the requirement	kW	265.86	209.47



	Unit Cost for power	Rs./kWh	5.75	5.75
	Annual operating Hours	Hours	8760	8760.00
	Annual energy consumption	kWh /year	2328958.72	1834965.60
	Annual power Savings, kWh	kWh		493993.12
	Annual Savings	Rs. In Lakhs		28.40
	Proposed load	Kw		210.00
	Investment required in Lakhs	Rs, in lakhs		48.00
	Simple Payback period	In years		1.69
		In months		20.28

**A1.6**

<b>Energy Efficiency in Existing Pumping system by replacing inefficient motor ( No. 201)</b>				
	<b>Description Unit</b>	<b>Uni t</b>	<b>Old System</b>	<b>New System</b>
	Type of Motor	Induction		
	Class of Motor		Standard	IE2
	Motor power (rated)	Kw	220.00	210.00
	Efficiency (rated)	%	95.50	95.50
	Combined system efficiency of the system (measured)	%	63.93	
	Pump efficiency	%		78.00
	The combined efficiency of the system (rated)	%	70.00	74.49
<b>Requirement</b>	Head	m	38.70	38.70
	Flow	m <sup>3</sup> /s	0.41	0.41
	Density of water	kg/m <sup>3</sup>	1000.00	1000.00
	Gravitational Constant	m/s <sup>2</sup>	9.81	9.81



	Hydraulic Power is required to meet the demand by existing pump set	kW	156.03	156.03
	Total Electrical Power drawn to meet the requirement	kW	244.07	209.47
	Unit Cost for power	Rs./kWh	5.75	5.75
	Annual operating Hours	Hours	8760.00	8760.00
	Annual energy consumption	kWh /year	2138066.44	1834965.60
	Annual power Savings, kWh	kWh		303100.84
	Annual Savings	Rs. In Lakhs		17.43
	Proposed load	Kw		210.00
	Investment required in Lakhs	Rs, in lakhs		48.00
	Simple Payback period	In years		2.75
		In months		33.05



ANNEXURE.2. PRELIMINARY AUDIT NOTE



**KERALA WATER AUTHORITY  
TEAM ENERGY MANAGEMENT UNIT**

Ref: KWA/JP/EW/EMC/EA/7813/2019 Dtd. 17/09/2021

CAMP OFFICE, PANAMKUTTYMALA.

Mob. : 9447222494, e-mail ID: thampisujana@gmail.com

Date: 31/10/2021

**PRIMARY AUDIT NOTE**

It is requested that the following changes can be made in the mode of operation of WTP.

- 1) The water level in the sump has to be maintained at least 4 m during pumping if possible to get an average of 3.5 m.
- 2) The non-loaded transformer may be kept as a standby and the loading operation may be interchanged once in two or three months.

Team Leader

S/d

(Thampy S)

Energy Audit Team