

Website: www.kwa.kerala.gov.in
Mail: 1916cckwa@gmail.com
Mobile / WhatsApp No: +919495998258

Tel. 0471-2738300
Consumer Helpline Number
1916 [24X7] [Toll Free]



KERALA WATER AUTHORITY

Jalabhavan
Thiruvananthapuram – 695033
Kerala – India

No. KWA-JB/4298/2024-AE(SP)

Dated 03-01-2025

From

The Chief Engineer (HRD & GL)

To

The Executive Engineers
PH/ WS/ HW/ QC Divisions

Sir / Madam,

Sub: - Supply and delivery of Hydrated Lime Grade C on Running Contract basis for Water treatment to various Divisions under Southern, Central, Northern Region of KWA -for the year 2024-25 -
Amendment on Supply order

Read:- 1. This office Supply order dated 10.09.2024 of CE (HRD & GL).
2. Request received from the firm M/s. Popular Limeshell Industries dtd.18.12.2024

Attention is invited to the subject matter and references cited above. Some queries were raised by M/s Popular Lime shell Industries regarding the Ca(OH)_2 content as per supply order vide reference (1) cited above. Based on the representation received vide reference (2), a discussion was held in the chamber of the Technical Member with the firm in the presence of officials, and it has been decided to issue a direction to all Field officers regarding Clause No. 7, (Acceptance of Supply) in the Supply order. Hence, the Supply order is hereby amended to specify that rejection of

supply has to be effected if Ca(OH)_2 content is below 80% and a proportionate reduction in payment shall be applied for Ca(OH)_2 content between 80% and 86%, up to for consignments supplied till **31st December 2024**.

For consignments supplied after 31st December 2024, the minimum Ca(OH)_2 content of hydrated lime should be 86% or above and the consignment supplied after 31/12/2024 shall be rejected if the Ca(OH)_2 content falls below 86%.

Yours faithfully,

CHIEF ENGINEER (HRD & GL)

Copy to : M/s Popular Lime Shell Industries,
Manjummel P O,
Udyogamandal -
Ernakulam, Kerala.
Pin - 633501.